

PROJECT: WATERPROOFING WORKS OF MAIN OFFICE, BAGUIO AND DAVAO BUILDINGS

QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:

	Query/Clarifications	TWG/BAC Reply
1	<p>Key Personnel</p> <p>If we participate on three (3) lots, can we have the same project manager for Manila, Davao, and Baguio?</p>	<p>At least two project managers will be required.</p> <p>1 – Manila and Baguio 1 – Davao</p> <p>Provided that project timeline and duration will be meet.</p>
2	<p>Regarding the required equipment, jack hammer with compressor, 40lbs. can we use chipping gun instead?</p>	<p>Minimum requirement shall be:</p> <p>Demolition Hammer/ Jackhammer / Chipping Gun Weight: 5-6 kgs Continuous rating input: 900W Impacts per Minute (IPM): 2,900</p>
3	<p>Do we have to provide truck for every lot?</p>	<p>Yes. Minimum requirement is one (1) truck for every lot/location.</p>
4	<p>Can we bid on lots 1 and 2 only?</p>	<p>Yes.</p>
5	<p>Is the bidding per lot?</p>	<p>Yes, and shall be awarded as separate contracts per lot.</p>