

PROJECT: SUPPLY AND DELIVERY OF LIGHTING FIXTURES FOR SSS MAIN BUILDING

A. QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:

	Query/Clarifications	TWG/BAC Reply
1	Lamp Size Would it be possible if our offer is 70*134 instead of 70*132	Yes, it is acceptable. We will include it in the Bid Bulletin.
2	Placement of the light Where do we put the light ?	Downlight.
3	Request Is it possible to extend the delivery period from 30 calendar days to 60 calendar days?	Yes, since all the bidders present here today are requesting to extend the delivery period, we shall include it also in the Bid Bulletin

B. REPLY TO WRITTEN QUERIES:

	Query/Clarifications	TWG/BAC Reply
1	Section VI: Schedule of Requirements We would like to request additional delivery date for the schedule of requirements	The delivery period of the project will be adjusted from 30 to 60 calendar days upon receipt of Notice to Proceed and Purchase Order due to ordering and Shipping of the imported products from the other country. This amends Section VI. Schedule of Requirements.
2	Technical Specifications, Item no. 3 For Technical Specification, Item No. 3 LED Bulb 15Watts Daylight.	Tech specs changed to: Technical Characteristics: Luminous Flux: 1300 Lm min. Size: 70-75* 132-147mm Average Lifetime Hrs.: 10,000 hours min. This amends Section VII. Technical Specifications.
3	Technical Specifications, for Item nos. 1, 2, 4, 5 & 6 - PNS Mark or ICC Sticker	Since LED Tubes and LED Flood Lights are not included in the list of products under BPS Mandatory Certifications, we

	Query/Clarifications	TWG/BAC Reply
	<p>Regarding on the PNS Mark or ICC Sticker for the following items.</p> <ul style="list-style-type: none"> a. LED Tube Light, 4Ft, T8, 18 watts b. LED Tube Light, 2Ft, T8, 9 watts c. LED Downlight, 18 watts, Daylight d. LED Floodlight, 150 watts, (2pcs *75 watts COB) e. LED Floodlight, 20 watts, (1pc. COB) 	<p>will be requiring RoHS/ UL/ CE compliant or its equivalent specified in the product or brochures.</p> <p>This amends Section VII. Technical Specifications.</p>