

PROJECT: SERVICING OF POWER SUBSTATION 1 AND 2

QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:

	Query/Clarifications	TWG/BAC Reply
1	<p>Where is the project located?</p> <p>Can the bidder conduct site inspection?</p> <p>Clarification on the site inspection, in case unavailable tomorrow, when is the next schedule?</p>	<p>SSS Main Office, East Avenue, Diliman, Quezon City.</p> <p>Yes.</p> <p>Bidder may conduct site inspection until Friday, 14 April 2023.</p>
2	Additional Instruction	
	<p>a. Conduct of site inspection before submission and opening of bids is mandatory. Engineering and Facilities Management Department (EFMD) will issue certificate of inspection.</p> <p>b. Please see additional Technical Specifications.</p> <p>b.1 The bidder must own the degasification equipment/machine. Proof of ownership must be supported with valid documents such Official receipt (OR) and/or a notarized affidavit stating the ownership of equipment/machine.</p> <p>b.2 The bidder must own a boom truck, which will be used for disconnecting/connecting and cleaning the load break switch and power fuses at the top of the receiving structure tower. Proof of ownership must be supported with valid documents such Official receipt (OR) and/or a notarized affidavit stating the ownership of the boom truck.</p> <p>Please see revised Section VII Technical Specifications. This amends Section VII Technical Specifications of the Bidding Documents.</p>	