

**PROJECT: PREVENTIVE MAINTENANCE OF SEWERAGE TREATMENT PLANT AT HONG KONG SUN PLAZA PROPERTY (RE-ADVERTISEMENT)**

**QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:**

	<b>Query/Clarifications</b>	<b>TWG/BAC Reply</b>
1	Can we visit/inspect the site?	Yes. Bidders may coordinate with the Building Administrator at Hong Kong Sun Plaza.

**WRITTEN QUERIES:**

	<b>Query/Clarifications</b>	<b>TWG/BAC Reply</b>
1	<p>ECOSYSTEMS TECHNOLOGIES: BDS – ITB Clause 5.3 We understand that the existing system is running ECR and the bidder must have an experience operating and maintaining a similar (ECR) system.</p> <p>- This required experience/ similar project is very specific and already limit the number of bidders that can join the project. With this, may we request to revise and/or consider this qualification</p> <p>– Operation and Maintenance of STP compliant to latest DENR requirements. Since, the goal of this project is to successfully O&amp;M the STP and to comply to DENR requirements all the time.</p>	<p>We will be reiterating our requirement that the similar experience of prospective bidders should be operating and maintaining a STP with an ElectroContaminant Remover (ECR) System to alleviate the possible longer downtime of the STP in case of repairs, since the new Service Provider will have to study first the operation of the STP-ECR System.</p>