

PROJECT: EMERGENCY LIGHTS FOR VARIOUS OFFICES**QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:**

	Query/Clarifications	TWG/BAC Reply
1	Can we still participate even without the SLCC? Do we have other option, or we allowed to submit an affidavit of "NO SLCC?"	No. SLCC is a mandatory requirement since this is procurement of goods.
2	It is indicated in the bidding documents that the required watt for the LED is 3-5 watts, is it ok to use 3 watts only?	Yes, it is acceptable.

WRITTEN QUERIES:

	Query/Clarifications	TWG/BAC Reply
1	Allow CE, UL or ETL and RoHS certification as approved equivalent for the Philippine National Standard (PNS)/ IEC Standard	Yes, we allow CE, UL or ETL and RoHS certification as approved equivalent for the Philippine National Standard (PNS)/ IEC Standard for as long as compliance with technical specification
2	Please extend the Delivery schedule from 30 days to 45 days.	The requested extension of the delivery period from 30 to 45 calendar days is granted.
3	Kindly provide a sample picture of your Emergency Lights	Sample pictures of Emergency Light 