



**SOCIAL SECURITY SYSTEM**

**PHILIPPINE BIDDING DOCUMENTS**


**Sixth Edition**

# **Procurement of GOODS**

**SUPPLY, DELIVERY AND INSTALLATION  
OF AIR – CONDITIONING UNITS AT  
CALBAYOG AND DAVAO – ILUSTRE  
BRANCHES**

**ITB-SSS-Goods-2023-086**

**Government of the Republic of the Philippines  
OCTOBER 2023**

  
**ANTONIO V. TRINOS, JR.**  
**TWG Chairperson**

# Table of Contents

**Glossary of Acronyms, Terms, and Abbreviations ..... 3**

**Section I. Invitation to Bid ..... 6**

**Section II. Instructions to Bidders ..... 9**

1. Scope of Bid ..... 10

2. Funding Information ..... 10

3. Bidding Requirements ..... 10

4. Corrupt, Fraudulent, Collusive, and Coercive Practices ..... 10

5. Eligible Bidders ..... 10

6. Origin of Goods ..... 11

7. Subcontracts ..... 11

8. Pre-Bid Conference ..... 11

9. Clarification and Amendment of Bidding Documents ..... 11

10. Documents comprising the Bid: Eligibility and Technical Components ..... 11

11. Documents comprising the Bid: Financial Component ..... 12

12. Bid Prices ..... 12

13. Bid and Payment Currencies ..... 13

14. Bid Security ..... 13

15. Sealing and Marking of Bids ..... 13

16. Deadline for Submission of Bids ..... 13

17. Opening and Preliminary Examination of Bids ..... 13

18. Domestic Preference ..... 14

19. Detailed Evaluation and Comparison of Bids ..... 14

20. Post-Qualification ..... 14

21. Signing of the Contract ..... 15

**Section III. Bid Data Sheet ..... 16**

**Section IV. General Conditions of Contract ..... 19**

1. Scope of Contract ..... 20

2. Advance Payment and Terms of Payment ..... 20

3. Performance Security ..... 20

4. Inspection and Tests ..... 20

5. Warranty ..... 20

6. Liability of the Supplier ..... 21

**Section V. Special Conditions of Contract ..... 22**

**Section VI. Schedule of Requirements ..... 37**

**Section VII. Technical Specifications ..... 38**

**Section VIII. Checklist of Technical and Financial Documents ..... 43**



# ***Glossary of Acronyms, Terms, and Abbreviations***

**ABC** – Approved Budget for the Contract.

**BAC** – Bids and Awards Committee.

**Bid** – A signed offer or proposal to undertake a contract submitted by a bidder in response to and in consonance with the requirements of the bidding documents. Also referred to as *Proposal* and *Tender*. (2016 revised IRR, Section 5[c])

**Bidder** – Refers to a contractor, manufacturer, supplier, distributor and/or consultant who submits a bid in response to the requirements of the Bidding Documents. (2016 revised IRR, Section 5[d])

**Bidding Documents** – The documents issued by the Procuring Entity as the bases for bids, furnishing all information necessary for a prospective bidder to prepare a bid for the Goods, Infrastructure Projects, and/or Consulting Services required by the Procuring Entity. (2016 revised IRR, Section 5[e])

**BIR** – Bureau of Internal Revenue.

**BSP** – Bangko Sentral ng Pilipinas.

**Consulting Services** – Refer to services for Infrastructure Projects and other types of projects or activities of the GOP requiring adequate external technical and professional expertise that are beyond the capability and/or capacity of the GOP to undertake such as, but not limited to: (i) advisory and review services; (ii) pre-investment or feasibility studies; (iii) design; (iv) construction supervision; (v) management and related services; and (vi) other technical services or special studies. (2016 revised IRR, Section 5[i])

**CDA** - Cooperative Development Authority.

**Contract** – Refers to the agreement entered into between the Procuring Entity and the Supplier or Manufacturer or Distributor or Service Provider for procurement of Goods and Services; Contractor for Procurement of Infrastructure Projects; or Consultant or Consulting Firm for Procurement of Consulting Services; as the case may be, as recorded in the Contract Form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.

**CIF** – Cost Insurance and Freight.

**CIP** – Carriage and Insurance Paid.

**CPI** – Consumer Price Index.

**DDP** – Refers to the quoted price of the Goods, which means “delivered duty paid.”

**DTI** – Department of Trade and Industry.

**EXW** – Ex works.

**FCA** – “Free Carrier” shipping point.

**FOB** – “Free on Board” shipping point.

**Foreign-funded Procurement or Foreign-Assisted Project**– Refers to procurement whose funding source is from a foreign government, foreign or international financing institution as specified in the Treaty or International or Executive Agreement. (2016 revised IRR, Section 5[b]).

**Framework Agreement** – Refers to a written agreement between a procuring entity and a supplier or service provider that identifies the terms and conditions, under which specific purchases, otherwise known as “Call-Offs,” are made for the duration of the agreement. It is in the nature of an option contract between the procuring entity and the bidder(s) granting the procuring entity the option to either place an order for any of the goods or services identified in the Framework Agreement List or not buy at all, within a minimum period of one (1) year to a maximum period of three (3) years. (GPPB Resolution No. 27-2019)

**GFI** – Government Financial Institution.

**GOCC** – Government-owned and/or –controlled corporation.

**Goods** – Refer to all items, supplies, materials and general support services, except Consulting Services and Infrastructure Projects, which may be needed in the transaction of public businesses or in the pursuit of any government undertaking, project or activity, whether in the nature of equipment, furniture, stationery, materials for construction, or personal property of any kind, including non-personal or contractual services such as the repair and maintenance of equipment and furniture, as well as trucking, hauling, janitorial, security, and related or analogous services, as well as procurement of materials and supplies provided by the Procuring Entity for such services. The term “related” or “analogous services” shall include, but is not limited to, lease or purchase of office space, media advertisements, health maintenance services, and other services essential to the operation of the Procuring Entity. (2016 revised IRR, Section 5[r])

**GOP** – Government of the Philippines.

**GPPB** – Government Procurement Policy Board.

**INCOTERMS** – International Commercial Terms.

**Infrastructure Projects** – Include the construction, improvement, rehabilitation, demolition, repair, restoration or maintenance of roads and bridges, railways, airports, seaports, communication facilities, civil works components of information technology projects, irrigation, flood control and drainage, water supply, sanitation, sewerage and solid waste management systems, shore protection, energy/power and electrification facilities, national buildings, school buildings, hospital buildings, and other related construction projects of the government. Also referred to as *civil works or works*. (2016 revised IRR, Section 5[u])

**LGUs** – Local Government Units.

**NFCC** – Net Financial Contracting Capacity.

**NGA** – National Government Agency.

**PhilGEPS** - Philippine Government Electronic Procurement System.

**Procurement Project** – refers to a specific or identified procurement covering goods, infrastructure project or consulting services. A Procurement Project shall be described, detailed, and scheduled in the Project Procurement Management Plan prepared by the agency which shall be consolidated in the procuring entity's Annual Procurement Plan. (GPPB Circular No. 06-2019 dated 17 July 2019)

**PSA** – Philippine Statistics Authority.

**SEC** – Securities and Exchange Commission.

**SLCC** – Single Largest Completed Contract.

**SSS** – Social Security System

**Supplier** – refers to a citizen, or any corporate body or commercial company duly organized and registered under the laws where it is established, habitually established in business and engaged in the manufacture or sale of the merchandise or performance of the general services covered by his bid. (Item 3.8 of GPPB Resolution No. 13-2019, dated 23 May 2019). Supplier as used in these Bidding Documents may likewise refer to a distributor, manufacturer, contractor, or consultant.

**UN** – United Nations.

## ***Section I. Invitation to Bid***



REPUBLIC OF THE PHILIPPINES  
**SOCIAL SECURITY SYSTEM**  
East Avenue, Diliman, Quezon City  
Tel. Nos. (632)8709-7198\*(632)8920-6446  
E-mail: [member\\_relations@sss.gov.ph](mailto:member_relations@sss.gov.ph)\*Website <http://www.sss.gov.ph>

**Invitation to Bid**  
**ITB-SSS-Goods-2023-086**

**SUPPLY, DELIVERY AND INSTALLATION OF AIR-CONDITIONING UNITS AT  
CALBAYOG AND DAVAO – ILUSTRE BRANCHES**

Approved Budget for the Contract (ABC) & Source of Fund	Delivery/ Completion Period	Price of Bid Documents (non-refundable)	Schedule of Activities Date/Time	
			Pre-bid Conference	Deadline of submission and receipt of bids
<p><b>₱ 3,277,155.00</b></p> <p><b>Broken down as follows:</b></p> <p>Lot 1 – Calbayog Branch</p> <p><b>₱ 2,151,795.00</b></p>	Thirty (30) Calendar Days upon receipt of Notice to Proceed and Signed Contract	<p><b>₱ 3,000.00</b></p>	<p>October 25, 2023 (Wednesday) 2:00pm</p>	<p>November 7, 2023 (Tuesday) 2:00pm</p>
<p>Lot 2 – Davao – Ilustre Branch</p> <p><b>₱ 1,125,360.00</b></p>		<p><b>₱ 2,000.00</b></p>		
Approved 2023 Corporate Operating Budget under Capital Outlay with Code PAP 2023-0223 of the Annual Procurement Plan (APP)				

1. The **SOCIAL SECURITY SYSTEM** now invites Bids for the above item. Delivery of the Goods is required within the period specified above. **Bidders should have completed within five (5) years prior to the date of submission and receipt of bids**, a contract similar to the Project. The description of an eligible Bidder is contained in the Bidding Documents, particularly, in Section II - Instruction to Bidders.
2. Bids received in excess of the ABC shall be automatically rejected at bid opening.
3. Bidding will be conducted through open competitive bidding procedures using a non-discretionary pass/fail criterion as specified in the 2016 Revised Implementing Rules and Regulations (RIRR) of Republic Act 9184 (RA) 9184, otherwise known as the “Government Procurement Reform Act”.

Bidding is restricted to Filipino citizens/sole proprietorships, partnerships, or organizations with at least sixty percent (60%) interest or outstanding capital stock belonging to citizens of the Philippines, and to citizens or organizations of a country the laws or regulations of which grant similar rights or privileges to Filipino citizens, pursuant to RA 5183.

4. Interested bidders may obtain further information from the SSS and inspect the Bidding Documents at the address in the last item of the ITB from Monday to Friday, 8:00 a.m. to 5:00 p.m.
5. A complete set of Bidding Documents may be acquired by interested bidders starting **17 October 2023 up to the scheduled submission & receipt of bids** from the address stated in the last item of the ITB and upon payment of the applicable fee for the Bidding Documents in the amount specified above.

The mode of payment will be on a cash basis payable at the SSS Cash Department, Ground Floor, SSS Main Bldg., upon accomplishment of SSS Form R-6. The Bidding Documents shall be received personally by the prospective Bidder or his authorized representative.

It may also be downloaded free of charge from the website of the Philippine Government Electronic Procurement System (PhilGEPS) and the website of the SSS, provided that Bidders shall pay the applicable fee for the Bidding Documents not later than the submission of their bids.

6. The SSS will hold a Pre-Bid Conference on the date and time specified above at the Bidding Room, 2<sup>nd</sup> Floor, SSS Main Bldg., East Avenue, Diliman, Quezon City which shall be open to prospective bidders, but attendance shall not be mandatory. To ensure completeness and compliance of bids, bidders are advised to send their authorized technical and/or administrative representatives who will prepare the bid documents.

**The Pre-Bid Conference will be conducted through online conference using Microsoft Teams. Kindly e-mail us on or before 24 October 2023, through e-mail address [bac@sss.gov.ph](mailto:bac@sss.gov.ph), the following:**

- a. **Name of the representative and e-mail address; and**
  - b. **Technical and administrative queries.**
7. Bids must be duly received by the BAC Secretariat at the Bidding Room, 2<sup>nd</sup> Floor, SSS Main Building, East Avenue, Diliman, Quezon City on the deadline specified above. All Bids must be accompanied by a bid security in any of the acceptable forms and in the amount stated in the ITB Clause 14.
- Bid opening shall be on the date and time specified above at the Bidding Room, 2<sup>nd</sup> Floor, SSS Main Building, East Avenue, Diliman, Quezon City. Bids will be opened in the presence of the bidders' representatives who choose to attend at the address above. Late bids shall not be accepted.
8. References to the dates and times shall be based on Philippine Standard time. Should any of the above dates fall on a holiday, the deadline shall be extended to the same time of the immediately succeeding business day in Quezon City.
9. The SSS reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised IRR of RA No. 9184, without thereby incurring any liability to the affected bidder or bidders.
10. The SSS assumes no obligation to compensate or indemnify parties for any expense or loss that they may incur as a result of their participation in the procurement process, nor does SSS guarantee that an award will be made as a result of this invitation. Furthermore, the SSS reserves the right to waive any defects or formality in the responses to the eligibility requirements and to this invitation and reserves the right to accept the proposal most advantageous to the agency.
11. For further information, please refer to:

**Bids & Awards Committee**

**The Secretariat**

2<sup>nd</sup> Flr., SSS Main Bldg., East Ave., Diliman, Q.C.

Tel # (632) 8922-1070; 8709-7198 local 5492/6382

Email – [bac@sss.gov.ph](mailto:bac@sss.gov.ph)

12. Bidding Documents may be downloaded from PROCUREMENT tab at [www.sss.gov.ph](http://www.sss.gov.ph) starting **17 October 2023**.

  
**THE VICE-CHAIRPERSON  
BIDS & AWARDS COMMITTEE**



## ***Section II. Instructions to Bidders***

## 1. Scope of Bid

The Procuring Entity, *Social Security System* wishes to receive Bids for the Supply, Delivery and Installation of Air-Conditioning Units at Calbayog and Davao – Ilustre Branches with identification number *ITB-SSS-Goods-2023-086*.

The Procurement Project (referred to herein as “Project”) is composed of *two (2) lots*, the details of which are described in Section VII (Technical Specifications).

## 2. Funding Information

- 2.1. The GOP through the source of funding as indicated below for *CY2023* in the amount of Three Million Four Hundred Two Thousand Four Hundred Sixty – Five Pesos (₱ 3,402,465.00).
- 2.2. The source of funding is: Approved 2023 Corporate Operating Budget under Capital Outlay with Code PAP 2023-0223 of the APP.

## 3. Bidding Requirements

The Bidding for the Project shall be governed by all the provisions of RA No. 9184 and its 2016 revised IRR, including its Generic Procurement Manuals and associated policies, rules and regulations as the primary source thereof, while the herein clauses shall serve as the secondary source thereof.

Any amendments made to the IRR and other GPPB issuances shall be applicable only to the ongoing posting, advertisement, or **IB** by the BAC through the issuance of a supplemental or bid bulletin.

The Bidder, by the act of submitting its Bid, shall be deemed to have verified and accepted the general requirements of this Project, including other factors that may affect the cost, duration and execution or implementation of the contract, project, or work and examine all instructions, forms, terms, and project requirements in the Bidding Documents.

## 4. Corrupt, Fraudulent, Collusive, and Coercive Practices

The Procuring Entity, as well as the Bidders and Suppliers, shall observe the highest standard of ethics during the procurement and execution of the contract. They or through an agent shall not engage in corrupt, fraudulent, collusive, coercive, and obstructive practices defined under Annex “I” of the 2016 revised IRR of RA No. 9184 or other integrity violations in competing for the Project.

## 5. Eligible Bidders

- 5.1. Only Bids of Bidders found to be legally, technically, and financially capable will be evaluated.
- 5.2. Foreign ownership limited to those allowed under the rules may participate in this Project.
  - a. Foreign ownership exceeding those allowed under the rules may participate pursuant to:
    - i. When a Treaty or International or Executive Agreement as provided in Section 4 of the RA No. 9184 and its 2016 revised IRR allow foreign bidders to participate;

- ii. Citizens, corporations, or associations of a country, included in the list issued by the GPPB, the laws or regulations of which grant reciprocal rights or privileges to citizens, corporations, or associations of the Philippines;
    - iii. When the Goods sought to be procured are not available from local suppliers; or
    - iv. When there is a need to prevent situations that defeat competition or restrain trade.
  - b. Foreign ownership limited to those allowed under the rules may participate in this Project.
- 5.3. Pursuant to Section 23.4.1.3 of the 2016 revised IRR of RA No.9184, the Bidder shall have an SLCC that is at least one (1) contract similar to the Project the value of which, adjusted to current prices using the PSA's CPI, must be at least equivalent to:
- a. The Bidder must have completed a single contract that is similar to this Project, equivalent to at least fifty percent (50%) of the ABC.
- 5.4. The Bidders shall comply with the eligibility criteria under Section 23.4.1 of the 2016 IRR of RA No. 9184.

## 6. Origin of Goods

There is no restriction on the origin of goods other than those prohibited by a decision of the UN Security Council taken under Chapter VII of the Charter of the UN, subject to Domestic Preference requirements under **ITB** Clause 18.

## 7. Subcontracts

7.1. The Procuring Entity has prescribed that Subcontracting is not allowed.

## 8. Pre-Bid Conference

The Procuring Entity will hold a pre-bid conference for this Project on the specified date and time and either at its physical address **Bidding Room, 2nd Floor, SSS Main Bldg., East Avenue, Diliman, Quezon City** and/or through online conference using **Microsoft Teams** as indicated in paragraph 6 of the **IB**.

## 9. Clarification and Amendment of Bidding Documents

Prospective bidders may request for clarification on and/or interpretation of any part of the Bidding Documents. Such requests must be in writing and received by the Procuring Entity, either at its given address or through electronic mail indicated in the **IB**, at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.

## 10. Documents comprising the Bid: Eligibility and Technical Components

10.1. The first envelope shall contain the eligibility and technical documents of the Bid as specified in **Section VIII (Checklist of Technical and Financial Documents)**.

- 10.2. The Bidder's SLCC as indicated in **ITB** Clause 5.3 should have been completed within **the last five years** prior to the deadline for the submission and receipt of bids.
- 10.3. If the eligibility requirements or statements, the bids, and all other documents for submission to the BAC are in foreign language other than English, it must be accompanied by a translation in English, which shall be authenticated by the appropriate Philippine foreign service establishment, post, or the equivalent office having jurisdiction over the foreign bidder's affairs in the Philippines. Similar to the required authentication above, for Contracting Parties to the Apostille Convention, only the translated documents shall be authenticated through an apostille pursuant to GPPB Resolution No. 13-2019 dated 23 May 2019. The English translation shall govern, for purposes of interpretation of the bid.

## 11. Documents comprising the Bid: Financial Component

- 11.1. The second bid envelope shall contain the financial documents for the Bid as specified in **Section VIII (Checklist of Technical and Financial Documents)**.
- 11.2. If the Bidder claims preference as a Domestic Bidder or Domestic Entity, a certification issued by DTI shall be provided by the Bidder in accordance with Section 43.1.3 of the 2016 revised IRR of RA No. 9184.
- 11.3. Any bid exceeding the ABC indicated in paragraph 1 of the **IB** shall not be accepted.
- 11.4. For Foreign-funded Procurement, a ceiling may be applied to bid prices provided the conditions are met under Section 31.2 of the 2016 revised IRR of RA No. 9184.

## 12. Bid Prices

- 12.1. Prices indicated on the Price Schedule shall be entered separately in the following manner:
  - a. For Goods offered from within the Procuring Entity's country:
    - i. The price of the Goods quoted EXW (ex-works, ex-factory, ex-warehouse, ex-showroom, or off-the-shelf, as applicable);
    - ii. The cost of all customs duties and sales and other taxes already paid or payable;
    - iii. The cost of transportation, insurance, and other costs incidental to delivery of the Goods to their final destination; and
    - iv. The price of other (incidental) services, if any, listed in the **BDS**.
  - b. For Goods offered from abroad:
    - i. Unless otherwise stated in the **BDS**, the price of the Goods shall be quoted delivered duty paid (DDP) with the place of destination in the Philippines as specified in the **BDS**. In quoting the price, the Bidder shall be free to use transportation through carriers registered in any eligible country. Similarly, the Bidder may obtain insurance services from any eligible source country.

- ii. The price of other (incidental) services, if any, as listed in the **BDS**.

### 13. Bid and Payment Currencies

- 13.1. For Goods that the Bidder will supply from outside the Philippines, the bid prices may be quoted in the local currency or tradeable currency accepted by the BSP at the discretion of the Bidder. However, for purposes of bid evaluation, Bids denominated in foreign currencies, shall be converted to Philippine currency based on the exchange rate as published in the BSP reference rate bulletin on the day of the bid opening.
- 13.2. Payment of the contract price shall be made in Philippine Pesos.

### 14. Bid Security

- 14.1. The Bidder shall submit a Bid Securing Declaration or any form of Bid Security in the amount indicated in the **BDS**, which shall be not less than the percentage of the ABC in accordance with the schedule in the **BDS**.
- 14.2. The Bid and bid security shall be valid for *One Hundred Twenty (120) Calendar Days from the Date of the Bid Opening.* Any Bid not accompanied by an acceptable bid security shall be rejected by the Procuring Entity as non-responsive.

### 15. Sealing and Marking of Bids

Each Bidder shall submit one copy of the first and second components of its Bid.

The Procuring Entity may request additional hard copies and/or electronic copies of the Bid. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.

If the Procuring Entity allows the submission of bids through online submission or any other electronic means, the Bidder shall submit an electronic copy of its Bid, which must be digitally signed. An electronic copy that cannot be opened or is corrupted shall be considered non-responsive and, thus, automatically disqualified.

### 16. Deadline for Submission of Bids

- 16.1. The Bidders shall submit on the specified date and time and either at its physical address or through online submission as indicated in paragraph 7 of the **IB**.

### 17. Opening and Preliminary Examination of Bids

- 17.1. The BAC shall open the Bids in public at the time, on the date, and at the place specified in paragraph 7 of the **IB**. The Bidders' representatives who are present shall sign a register evidencing their attendance. In case videoconferencing, webcasting or other similar technologies will be used, attendance of participants shall likewise be recorded by the BAC Secretariat.

In case the Bids cannot be opened as scheduled due to justifiable reasons, the rescheduling requirements under Section 29 of the 2016 revised IRR of RA No. 9184 shall prevail.

- 17.2. The preliminary examination of bids shall be governed by Section 30 of the 2016 revised IRR of RA No. 9184.

## 18. Domestic Preference

- 18.1. The Procuring Entity will grant a margin of preference for the purpose of comparison of Bids in accordance with Section 43.1.2 of the 2016 revised IRR of RA No. 9184.

## 19. Detailed Evaluation and Comparison of Bids

- 19.1. The Procuring BAC shall immediately conduct a detailed evaluation of all Bids rated “*passed*,” using non-discretionary pass/fail criteria. The BAC shall consider the conditions in the evaluation of Bids under Section 32.2 of the 2016 revised IRR of RA No. 9184.
- 19.2. If the Project allows partial bids, bidders may submit a proposal on any of the lots or items, and evaluation will be undertaken on a per lot or item basis, as the case maybe. In this case, the Bid Security as required by **ITB** Clause 14 shall be submitted for each lot or item separately.
- 19.3. The descriptions of the lots or items shall be indicated in **Section VII (Technical Specifications)**, although the ABCs of these lots or items are indicated in the **BDS** for purposes of the NFCC computation pursuant to Section 23.4.2.6 of the 2016 revised IRR of RA No. 9184. The NFCC must be sufficient for the total of the ABCs for all the lots or items participated in by the prospective Bidder.
- 19.4. The Project shall be awarded as follows:  
  
One Project having several items grouped into several lots, which shall be awarded as separate contracts per lot.
- 19.5. Except for bidders submitting a committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation, all Bids must include the NFCC computation pursuant to Section 23.4.1.4 of the 2016 revised IRR of RA No. 9184, which must be sufficient for the total of the ABCs for all the lots or items participated in by the prospective Bidder. For bidders submitting the committed Line of Credit, it must be at least equal to ten percent (10%) of the ABCs for all the lots or items participated in by the prospective Bidder.

## 20. Post-Qualification

- 20.1. *[Include if Framework Agreement will be used:]* For multi-year Framework Agreement, all bidders initially determined to be eligible and financially compliant shall be subject to initial post-qualification. The BAC shall then recommend the execution of a Framework Agreement among all eligible, technically and financially compliant bidders and the Procuring Entity and shall be issued by HoPE a Notice to Execute Framework Agreement. The determination of the Lowest Calculated Bid (LCB) shall not be performed by the BAC until a Mini-Competition is conducted among the bidders who executed a Framework Agreement. When a Call for Mini-Competition is made, the BAC shall allow the bidders to submit their best financial proposals on such pre-scheduled date, time and place to determine the bidder with the LCB.

- 20.2. Within a non-extendible period of five (5) calendar days from receipt by the Bidder of the notice from the BAC that it submitted the Lowest Calculated Bid, the Bidder shall submit its latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS) and other appropriate licenses and permits required by law and stated in the **BDS**.

## **21. Signing of the Contract**

- 21.1. The documents required in Section 37.2 of the 2016 revised IRR of RA No. 9184 shall form part of the Contract. Additional Contract documents are indicated in the **BDS**.

***Section III. Bid Data Sheet***





# Bid Data Sheet

ITB Clause										
5.3	<p>For this purpose, contracts similar to the Project shall be:</p> <p>a. Supply, Delivery and Installation of Packaged Type Air – Conditioning Units</p> <p>b. Completed within five (5) years prior to the deadline for the submission and receipt of bids.</p>									
7.1	Not Applicable									
12	The price of the Goods shall be quoted DDP. Delivery sites are stated in GCC Clause no.1 of Section V. Special Conditions of Contract									
14.1	<p>The bid security shall be in the form of a Bid Securing Declaration, or any of the following forms and amounts:</p> <table><tr><th>Form of Bid Security</th><th>Amount of Bid Security (Not less than the Percentage of the ABC)</th></tr><tr><td>Cash or cashier’s/manager’s check issued by a Universal or Commercial Bank.</td><td rowspan="2">Two percent (2%) or Lot 1: ₱ 22,507.20 Lot 2: ₱ 43,035.90</td></tr><tr><td>Bank draft/guarantee or irrevocable letter of credit issued by a Universal or Commercial Bank: Provided, however, that it shall be confirmed or authenticated by a Universal or Commercial Bank, if issued by a foreign bank.</td></tr><tr><td>Surety bond callable upon demand issued by a surety or insurance company duly certified by the Insurance Commission as authorized to issue such security.</td><td>Five percent (5%) or Lot 1: ₱ 56,268.00 Lot 2: ₱ 107,589.75</td></tr></table> <p>* Bank issued securities must be issued by a universal/commercial bank.</p> <p>* Surety Bonds must be accompanied by a certification from Insurance Commission that issuer is authorized to issue such security.</p> <p>* Bid Securing Declaration must be notarized by a duly commissioned Notary Public.</p>	Form of Bid Security	Amount of Bid Security (Not less than the Percentage of the ABC)	Cash or cashier’s/manager’s check issued by a Universal or Commercial Bank.	Two percent (2%) or Lot 1: ₱ 22,507.20 Lot 2: ₱ 43,035.90	Bank draft/guarantee or irrevocable letter of credit issued by a Universal or Commercial Bank: Provided, however, that it shall be confirmed or authenticated by a Universal or Commercial Bank, if issued by a foreign bank.	Surety bond callable upon demand issued by a surety or insurance company duly certified by the Insurance Commission as authorized to issue such security.	Five percent (5%) or Lot 1: ₱ 56,268.00 Lot 2: ₱ 107,589.75		
Form of Bid Security	Amount of Bid Security (Not less than the Percentage of the ABC)									
Cash or cashier’s/manager’s check issued by a Universal or Commercial Bank.	Two percent (2%) or Lot 1: ₱ 22,507.20 Lot 2: ₱ 43,035.90									
Bank draft/guarantee or irrevocable letter of credit issued by a Universal or Commercial Bank: Provided, however, that it shall be confirmed or authenticated by a Universal or Commercial Bank, if issued by a foreign bank.										
Surety bond callable upon demand issued by a surety or insurance company duly certified by the Insurance Commission as authorized to issue such security.	Five percent (5%) or Lot 1: ₱ 56,268.00 Lot 2: ₱ 107,589.75									
19.3	<p>The ABC is ₱ 3,277,155.00</p> <table><tr><th>Lot No.</th><th>Offices Covered</th><th>ABC</th></tr><tr><td>1</td><td>Calbayog Branch</td><td>₱ 1,125,360.00</td></tr><tr><td>2</td><td>Davao – Ilustre Branch</td><td>₱ 2,151,795.00</td></tr></table> <p>Any bid with a financial component exceeding the ABC per lot shall not be accepted.</p>	Lot No.	Offices Covered	ABC	1	Calbayog Branch	₱ 1,125,360.00	2	Davao – Ilustre Branch	₱ 2,151,795.00
Lot No.	Offices Covered	ABC								
1	Calbayog Branch	₱ 1,125,360.00								
2	Davao – Ilustre Branch	₱ 2,151,795.00								



20.1	Not Applicable.
20.2	<p>The Lowest Calculated Bidder shall submit the following:</p> <ol style="list-style-type: none"> <li>1. Registration certificate from Securities and Exchange Commission (SEC) for corporation including Articles of Incorporation and General Information Sheet (GIS), Department of Trade and Industry (DTI) for sole proprietorship, or Cooperative Development Authority (CDA) for cooperatives or its equivalent document</li> <li>2. Mayor's or Business permit issued by the city or municipality where the principal place of business of the prospective bidder is located, or the equivalent document for Exclusive Economic Zones or Areas;</li> <li>3. Tax clearance per E.O. No. 398, s. 2005, as finally reviewed and approved by the Bureau of Internal Revenue (BIR)</li> <li>4. Latest Audited Financial Statements</li> <li>5. Latest income tax return corresponding to the Audited Financial Statements submitted, filed electronically (EFPS);</li> <li>6. Quarterly VAT (business tax returns) per Revenue Regulations 3-2005 for the last six (6) months prior to the submission &amp; opening of bids filed electronically (EFPS);</li> </ol>
21.1	Not Applicable



*Section IV. General Conditions of Contract*



## 1. Scope of Contract

This Contract shall include all such items, although not specifically mentioned, that can be reasonably inferred as being required for its completion as if such items were expressly mentioned herein. All the provisions of RA No. 9184 and its 2016 revised IRR, including the Generic Procurement Manual, and associated issuances, constitute the primary source for the terms and conditions of the Contract, and thus, applicable in contract implementation. Herein clauses shall serve as the secondary source for the terms and conditions of the Contract.

This is without prejudice to Sections 74.1 and 74.2 of the 2016 revised IRR of RA No. 9184 allowing the GPPB to amend the IRR, which shall be applied to all procurement activities, the advertisement, posting, or invitation of which were issued after the effectivity of the said amendment.

Additional requirements for the completion of this Contract shall be provided in the **Special Conditions of Contract (SCC)**.

## 2. Advance Payment and Terms of Payment

2.1. Advance payment of the contract amount is provided under Annex “D” of the revised 2016 IRR of RA No. 9184.

2.2. The Procuring Entity is allowed to determine the terms of payment on the partial or staggered delivery of the Goods procured, provided such partial payment shall correspond to the value of the goods delivered and accepted in accordance with prevailing accounting and auditing rules and regulations. The terms of payment are indicated in the **SCC**.

## 3. Performance Security

Within ten (10) calendar days from receipt of the Notice of Award by the Bidder from the Procuring Entity but in no case later than the signing of the Contract by both parties, the successful Bidder shall furnish the performance security in any of the forms prescribed in Section 39 of the 2016 revised IRR of RA No. 9184.

## 4. Inspection and Tests

The Procuring Entity or its representative shall have the right to inspect and/or to test the Goods to confirm their conformity to the Project specifications at no extra cost to the Procuring Entity in accordance with the Generic Procurement Manual. In addition to tests in the **SCC, Section VII (Technical Specifications)** shall specify what inspections and/or tests the Procuring Entity requires, and where they are to be conducted. The Procuring Entity shall notify the Supplier in writing, in a timely manner, of the identity of any representatives retained for these purposes.

All reasonable facilities and assistance for the inspection and testing of Goods, including access to drawings and production data, shall be provided by the Supplier to the authorized inspectors at no charge to the Procuring Entity.

## 5. Warranty

5.1 In order to assure that manufacturing defects shall be corrected by the Supplier, a warranty shall be required from the Supplier as provided under Section 62.1 of the 2016 revised IRR of RA No. 9184.

- 5.2 The Procuring Entity shall promptly notify the Supplier in writing of any claims arising under this warranty. Upon receipt of such notice, the Supplier shall, repair or replace the defective Goods or parts thereof without cost to the Procuring Entity, pursuant to the Generic Procurement Manual.

## **6. Liability of the Supplier**

The Supplier's liability under this Contract shall be as provided by the laws of the Republic of the Philippines.

If the Supplier is a joint venture, all partners to the joint venture shall be jointly and severally liable to the Procuring Entity.

*Section V. Special Conditions of Contract*



# Special Conditions of Contract

GCC Clause	
1	<p data-bbox="326 363 690 401"><b>GENERAL CONDITIONS</b></p> <p data-bbox="326 443 1511 770">The work to be done consists of complete in all details, of the Electrical and Mechanical Works, at the subject premises, and all work and materials incidental to the proper completion of the mechanical work. All works shall be in accordance with the governing Codes and Regulations and with the Specifications, except where the same shall conflict with such Codes, etc., which shall then govern. The requirements in regard to materials and workmanship specify the required standards for the furnishing of all labor, materials, and appliances necessary for the complete installation of the work specified herein and indicated on the drawings. These specifications are intended to provide a broad outline of the required services, but are not limited to include all details of design.</p> <p data-bbox="326 812 1511 954">In case of deviation of the given design specification and modifications and correction shall be at the look out of the contractor to make the necessary adjustment such that the desired cooling requirement can be delivered in order to attain the sufficient provision of air-conditioning system to cool the area and satisfy the operation.</p> <p data-bbox="326 994 584 1031"><b>A. MECHANICAL</b></p> <ol data-bbox="363 1049 1511 1589" style="list-style-type: none"><li>1. All Indoor and Outdoor Units and its refrigerant and electrical lines shall be installed in accordance with the manufacturer's recommendations.</li><li>2. All refrigerant line installations shall be properly welded and secured against leaks and shall be also provided with insulators, appropriate rigid supports to secure the equipment against movement that may cause any from damages to its supporting components/ parts and equipment itself.</li><li>3. All necessary accessories shall be provided to system installations to ensure safe and proper operation of the equipment.</li><li>4. All suction and discharge lines shall be insulated with Rubber Insulation Size 25mm minimum thickness.</li><li>5. Provision of Rubber Insulation with polyethylene tape for all piping lines.</li><li>6. Connect Air-conditioning Unit drains to the nearest floor drain with 25mm dia. minimum size or install new floor drain line connections, if necessary.</li><li>7. Provision of Rubber Insulation pad to the mounting of the equipment/ unit to minimize and eliminate vibrations.</li></ol> <p data-bbox="326 1632 568 1669"><b>B. ELECTRICAL</b></p> <ol data-bbox="363 1687 1511 2088" style="list-style-type: none"><li>1. All electrical materials shall be approved type and application.</li><li>2. All electrical materials shall be in accordance with the plans, specification and in compliance with the Philippine National Standards (PNS), latest edition of the Philippine Electrical Code (PEC) and applicable Local Codes/ Regulations/ Laws.</li><li>3. All roughing – in layout shall be concealed with PVC or RSC or IMC.</li><li>4. All electrical pipe-fittings and insulation shall be provided with appropriate lock nut and bushing and appropriate supports with standards intervals.</li><li>5. Feeder and sub-feeder wiring shall be provided with adequate wire marker. Panels shall be provided with directory.</li><li>6. Testing, commissioning and proper documentations shall be made prior to turn-over of the completed project.</li></ol>



	<p><b>VISIT TO SITE</b></p> <p>The Contractor is required to conduct the site inspection in order for them/him to be familiar with the existing local conditions and include all necessary incidental works and materials that will be needed on the completion of the project. The proposal shall include all necessary considerations that may affect in the execution of all works. Subsequent claim(s) on the ground of inadequate or insufficient information shall not be entertained.</p> <p>All permits required for this work shall be obtained by and at the expense of the Contractor. The Contractor shall furnish the SSS the certificates of inspection and approval from the proper government authorities after the completion of the work. The Contractor shall prepare all as-built plans and all other paperwork required by the approving authorities.</p> <p><b>COORDINATION</b></p> <p>The Contractor shall coordinate in every work with all other Contractors to whose apparatus he shall connect part of his work, and also provide in his work connections and facilities for the connection of their work. The Contractor is hereby called upon to prepare such drawings of details of his equipment, location of sleeves, inserts and supports as may be required for the assistance, and the coordination of his work with that of the existing installation. Upon demand, he shall furnish these drawings in adequate numbers for the information to all parties concerned, and shall coordinate the preparation of these drawings by consultation with other trades involved, before submitting them. The approval of such drawings will not relieve Contractor in any way from the responsibility of proper location and coordinating his work with the SSS.</p> <p><b>MINOR MODIFICATIONS</b></p> <p>The plans are diagrammatic and do not necessarily show all fittings, etc., necessary to fit the building conditions. The locations of equipment/apparatus and appliances shown on them are approximate. The Contractor shall be responsible for the proper location in order to make them fit with electrical details and instruction from the SSS at the site.</p> <p><b>WORKMANSHIP</b></p> <p>The work shall be executed in the best and most thorough manner under the direction of and to the satisfaction of the Engineers, who will jointly interpret the meaning of the drawings and specifications and shall have the power to reject any work and materials in their judgments, are not in full accordance therewith.</p> <p>The Contractor shall have on file, for ready access and reference, a set of drawings indicating all work as actually installed incorporating in same all changes and additions. Open the termination of the Contract, he shall prepare set of tracings indication therein the electrical work as actually and finally installed. These drawings shall be turned over to the SSS.</p> <p><b>STANDARD OF MATERIALS</b></p> <p>All materials shall be new and shall conform with the standards of Philippine National Standards, (PNS) or the following; Underwriter's Laboratories, Inc., ASA, IEEE, NEMA, IPCEA and ASTM in every case where such a standard has been established for the particular type of materials in question. All materials on all system shall comply with the specifications, unless specifically exempted and all materials where not specified shall be of the best of their respective kind. Samples of any materials shall be submitted for approval as required by the Owner's Representative.</p> <p><b>PROTECTION</b></p> <p>Contractor shall protect his own work from damage during and, as may be necessary after the installation; and he shall likewise protect adjoining existing installation from damage resulting from installation of this work.</p>
--	---



	<b>CLEANING UP</b>	
	The Contractor shall remove all dirt, debris, rubbish and waste materials caused by him in the process of his work. He shall also remove all tools, temporary power installation, scaffolding and surplus materials after completion and acceptance of his work.	
	<b>Other Accessories (Materials for approval during project implementation)</b>	<b>Specification</b>
	<b>1. Pipe Insulation</b> Rubber Insulation to all suction and discharge lines	25mmØ Thick
	<b>2. Piping accessories and consumable materials</b> a. Insulation Tape b. Adhesive c. Welding works	White tape size 4” Contact Cement Oxy-acetylene and Silfus Rod
	<b>3. Drainage System</b> PVC pipe and fittings	1” diameter (minimum), shall be provided with clean-out for maintenance purposes
	<b>4. Mounting Platform, Hangers and Supports</b> a. Mounting Platform b. Hangers and Supports	Angle bar, 2” x 2” x 1/8” thick Shall be installed 6feet apart (minimum)
	<b>5. Conduits &amp; Fittings</b> a. 1/2inØ, 3/4inØ  b. 1/2inØ, 3/4inØ	PVC Conduit for wiring connections from FCU to ACCU  Liquid Tight Flexible Conduit, for wiring connections from ACCU wiring port to ECB
	<b>6. Boxes / Gutters with cover</b>	Steel Sheet Gauge No. 16
	<b>SCOPE OF WORKS –</b>	
	<b>LOT 1</b>	
	<b>A.</b>	<b>MECHANICAL</b>
	1.	All works shall be properly coordinated with SSS Representative/s
	2.	Any works and materials specification changes shall be discussed prior to the approval of SSS Representative/s
	3.	Supply, delivery and installation of <b>Three (3)</b> 3TR/4HP Ceiling Mounted/Suspended Inverter Split – type AC at the following locations of the relocation site of SSS Calbayog Branch: - ACU 101 at Administrative Section - ACU 102 at Accounts Management Section - ACU 103 at Medical Evaluation Center
	4.	Supply, delivery and installation of <b>Five (5)</b> 3TR/4HP Floor Mounted Inverter Split – type AC at the following locations of the relocation site of SSS Calbayog Branch: - ACU 104 at Info Counter and PACD



	<ul style="list-style-type: none"> <li>- ACU 105 at MSS Seating Area</li> <li>- ACU 106 at MSS Seating Area</li> <li>- ACU 107 at MSS Backroom</li> <li>- ACU 108 at e – Center</li> </ul>
5.	Supply, Delivery and Installation of <b>One (1)</b> 2.5HP Wall Mounted Inverter Split – Type Air – Conditioning Unit at the Teller Section (ACU 109) of the relocation site of SSS Calbayog Branch
6.	Supply, delivery and installation of <b>Three (3)</b> 2HP Wall Mounted Inverter Split – type AC at the following locations of the relocation site of SSS Calbayog Branch: <ul style="list-style-type: none"> <li>- ACU 110 at Office of the Branch Head</li> <li>- ACU 111 at Conference Room</li> <li>- ACU 112 at ID Capture</li> </ul>
7.	The ACCU and FCU shall be properly installed on a steel pedestal/platform base complete with vibration isolating medium like neoprene rubber pad
8.	Supply and installation of brand new refrigerant pipes, rubber insulation, suitable valves and fittings, rigid supports and other standard accessories essential to the piping system
9.	Thoroughly flush and purge the system using refrigerant flushing agents appropriate for the desired application. Leak testing the refrigerant piping system as recommended by the manufacturer
10.	The refrigerant system must be applied with pressure (-) 30mm Hg before charging it with refrigerant per manufacturer's instruction
11.	Final charging of the refrigerant must be applied to the system up to 250psig at high side and 60psig at low side or as manufacturer's recommendation
12.	Pipe runs shall be supported with rigid supports every two (2) meter interval (minimum) with appropriate brackets, rubber bushing and hangers, suitable for the installation and anchored with U-bolt fittings
13.	Drain lines to be installed shall be embedded and shall be with independent discharge headers dedicated for air-con drain only. Brand new drain lines may be tapped to the nearest rain drainage system. All drain system shall be equipped with appropriate clean-out and fittings, rigidly anchored with independent hangers and supports.
14.	Supply and installation of other essential, miscellaneous and incidental materials to complete the project
15.	All areas affected during implementation of the project by chipping, dismantling works and other related activities shall be restored to original aesthetic condition at the owner's satisfaction and to the sole account of the contractor
16.	Tools, testing equipment and instruction manuals and reference materials shall be provided prior to the proper Testing and Commissioning of the completed system. Test result shall be submitted to the Building Owner Representative.
17.	The supplier shall be responsible for repairs, periodic maintenance including semi – annual cleaning and servicing, check – up of the supplied A/C units for the entire duration of the warranty period
18.	Preparation and submission of delivery receipts, sales invoice, original JO/ PO, as-built plans, installation and operation manuals, brochures, and the start-up test result and other documents required in the project. The submitted as-built plans showing the mechanical load schedule, and the start-up test result, shall be used as cross references in validating the actual length of refrigerant piping with complementary

		peripherals accessories installed the same shall be the basis of establishing the proportionate calculation of the applicable additive and or deductive complementary to the provision under SCC 2.2.3, page 29 of this PBD.
	<b>B.</b>	<b>ELECTRICAL</b>
	1.	All works shall be properly coordinated with SSS representative/s
	2.	Supply and installation of the new feeder lines and conduits from Air-Cooled Condensing Units (ACCU) to Enclosed Circuit Breakers (ECB).
	3.	Supply and installation of wiring and roughing-ins for power circuits and corresponding field wiring and controls from indoor to outdoor units including its controller switch for all units
	4.	Supply and installation of brand new ECB's for all AC units
	5.	Use Liquid Tight Flexible conduit with appropriate wiring, fittings and supports from ECB towards the ACCU terminal/tapping lines
	6.	Electrical panels/enclosures, conduits, boxes shall be designed according to its intended design/purpose and application with appropriate supports and fittings and shall be rigidly secured using appropriate materials. Panel directory shall be properly labeled.
	7.	All areas affected during implementation of the project by chipping, dismantling works and other related activities shall be restored to original condition at the owner's satisfaction and to the sole account of the contractor
	8.	Perform megger testing of new and old lines to ensure safety against grounding or fault condition and submit test results. Implement rectification or troubleshooting if lines are found faulty
	9.	The bidders are encouraged to conduct site inspection to verify the actual site condition and the proposed location of ACCUs and FCUs.
	<b>LOT 2</b>	
	<b>A.</b>	<b>MECHANICAL</b>
	1.	All works shall be properly coordinated with SSS Representative/s
	2.	Any works and materials specification changes shall be discussed prior to the approval of SSS Representative/s
	3.	Supply, delivery and installation of <b>Three (3)</b> 3TR/4HP Ceiling Mounted/Suspended Inverter Split – type AC at the following locations of the relocation site of SSS Davao – Ilustre Branch: <ul style="list-style-type: none"> <li>- ACU 101 at AMS and MSS Backroom</li> <li>- ACU 102 at AMS and MSS Counters</li> <li>- ACU 103 at Administrative Section</li> </ul>
	4.	Supply, delivery and installation of <b>One (1)</b> 3TR/4HP Floor Mounted Inverter Split – type AC at Future Large Accounts Area (ACU 106) of the relocation site of SSS Davao – Ilustre Branch
	6.	Supply, delivery and installation of <b>Two (2)</b> 2HP Wall Mounted Inverter Split – type AC at the following locations of the relocation site of SSS Davao – Ilustre Branch: <ul style="list-style-type: none"> <li>- ACU 107 at Office of the Branch Head</li> <li>- ACU 108 at Conference Room</li> </ul>



	7.	Supply, Delivery and Installation of <b>One (1)</b> 2HP Window Type Room Air – Conditioner at Electrical Room (RA C 101) of the relocation site of SSS Davao – Ilustre Branch
	8.	The ACCU and FCU shall be properly installed on a steel pedestal/platform base complete with vibration isolating medium like neoprene rubber pad
	9.	Supply and installation of brand new refrigerant pipes, rubber insulation, suitable valves and fittings, rigid supports and other standard accessories essential to the piping system
	10.	Thoroughly flush and purge the system using refrigerant flushing agents appropriate for the desired application. Leak testing the refrigerant piping system as recommended by the manufacturer
	11.	The refrigerant system must be applied with pressure (-) 30mm Hg before charging it with refrigerant per manufacturer's instruction
	12.	Final charging of the refrigerant must be applied to the system up to 250psig at high side and 60psig at low side or as manufacturer's recommendation
	13.	Pipe runs shall be supported with rigid supports every two (2) meter interval (minimum) with appropriate brackets, rubber bushing and hangers, suitable for the installation and anchored with U-bolt fittings
	14.	Drain lines to be installed shall be embedded and shall be with independent discharge headers dedicated for air-con drain only. Brand new drain lines may be tapped to the nearest rain drainage system. All drain system shall be equipped with appropriate clean-out and fittings, rigidly anchored with independent hangers and supports.
	15.	Supply and installation of other essential, miscellaneous and incidental materials to complete the project
	16.	All areas affected during implementation of the project by chipping, dismantling works and other related activities shall be restored to original aesthetic condition at the owner's satisfaction and to the sole account of the contractor
	17.	Tools, testing equipment and instruction manuals and reference materials shall be provided prior to the proper Testing and Commissioning of the completed system. Test result shall be submitted to the Building Owner Representative.
	18.	The supplier shall be responsible for repairs, periodic maintenance including semi – annual cleaning and servicing, check – up of the supplied A/C units for the entire duration of the warranty period
	19.	Preparation and submission of delivery receipts, sales invoice, original JO/ PO, as-built plans, installation and operation manuals, brochures, and the start-up test result and other documents required in the project. The submitted as-built plans showing the mechanical load schedule, and the start-up test result, shall be used as cross references in validating the actual length of refrigerant piping with complementary peripherals accessories installed the same shall be the basis of establishing the proportionate calculation of the applicable additive and or deductive complementary to the provision under SCC 2.2.3, page 29 of this PBD.
	<b>B.</b>	<b>ELECTRICAL</b>
	1.	All works shall be properly coordinated with SSS representative/s
	2.	Supply and installation of the new feeder lines and conduits from Air-Cooled Condensing Units (ACCU) to Enclosed Circuit Breakers (ECB).



	3.	Supply and installation of wiring and roughing-ins for power circuits and corresponding field wiring and controls from indoor to outdoor units including its controller switch for all units
	4.	Supply and installation of brand new ECB's for all AC units
	5.	Use Liquid Tight Flexible conduit with appropriate wiring, fittings and supports from ECB towards the ACCU terminal/tapping lines
	6.	Electrical panels/enclosures, conduits, boxes shall be designed according to its intended design/purpose and application with appropriate supports and fittings and shall be rigidly secured using appropriate materials. Panel directory shall be properly labeled.
	7.	All areas affected during implementation of the project by chipping, dismantling works and other related activities shall be restored to original condition at the owner's satisfaction and to the sole account of the contractor
	8.	Perform megger testing of new and old lines to ensure safety against grounding or fault condition and submit test results. Implement rectification or troubleshooting if lines are found faulty
	9.	The bidders are encouraged to conduct site inspection to verify the actual site condition and the proposed location of ACCUs and FCUs.
	<p><b>Delivery and Documents –</b></p> <p>For purposes of the Contract, “EXW,” “FOB,” “FCA,” “CIF,” “CIP,” “DDP” and other trade terms used to describe the obligations of the parties shall have the meanings assigned to them by the current edition of INCOTERMS published by the International Chamber of Commerce, Paris. The Delivery terms of this Contract shall be as follows:</p> <p>The delivery of air – conditioning units shall be at the following sites:</p> <ul style="list-style-type: none"> <li>- For Lot 1: relocation site of Calbayog Branch located at University Town Center, Yrigan Road, Calbayog City, Samar</li> <li>- For Lott 2: relocation site of SSS Davao – Ilustre Branch located at Ground Floor, Oakwood Pines Acreage Corp. Building, San Pedro Street, Davao City</li> </ul> <p>Risk and title will pass from the Supplier to the Procuring Entity upon receipt and final acceptance of the Goods from <i>Designated Project-in-Charge from Branch Support Services Department (BSSD)</i></p> <p>Delivery of the Goods shall be made by the Supplier in accordance with the terms specified in Section VI (Schedule of Requirements).</p> <p>For purposes of this Clause the Procuring Entity's Representative is <i>Designated Project-in-Charge from Branch Support Services Department (BSSD) with telephone number (02) 87097198 locals 6119, 5939 and 5942.</i></p> <p><b>Incidental Services –</b></p> <p>The Supplier is required to provide all of the following services, including additional services, if any, specified in Section VI. Schedule of Requirements:</p> <ul style="list-style-type: none"> <li>a. performance or supervision of on-site assembly and/or start-up of the supplied Goods;</li> </ul>	



	<div data-bbox="391 191 1511 560"><ul style="list-style-type: none"><li>b. furnishing of tools required for assembly and/or maintenance of the supplied Goods;</li><li>c. furnishing of a detailed operations and maintenance manual for each appropriate unit of the supplied Goods;</li><li>d. performance or supervision or maintenance and/or repair of the supplied Goods, for a period of time agreed by the parties, provided that this service shall not relieve the Supplier of any warranty obligations under this Contract; and</li><li>e. training of the Procuring Entity’s personnel, at the Supplier’s plant and/or on-site, in assembly, start-up, operation, maintenance, and/or repair of the supplied Goods.</li></ul></div> <div data-bbox="324 598 1511 705"><p>The Contract price for the Goods shall include the prices charged by the Supplier for incidental services and shall not exceed the prevailing rates charged to other parties by the Supplier for similar services.</p></div> <div data-bbox="324 742 509 779"><p><b>Spare Parts –</b></p></div> <div data-bbox="324 817 1511 892"><p>The Supplier is required to provide all of the following materials, notifications, and information pertaining to spare parts manufactured or distributed by the Supplier:</p></div> <div data-bbox="402 929 1511 1358"><ul style="list-style-type: none"><li>1. such spare parts as the Procuring Entity may elect to purchase from the Supplier, provided that this election shall not relieve the Supplier of any warranty obligations under this Contract; and</li><li>2. in the event of termination of production of the spare parts:<ul style="list-style-type: none"><li>i. advance notification to the Procuring Entity of the pending termination, in sufficient time to permit the Procuring Entity to procure needed requirements; and</li><li>ii. following such termination, furnishing at no cost to the Procuring Entity, the blueprints, drawings, and specifications of the spare parts, if requested.</li></ul></li></ul></div> <div data-bbox="324 1395 1511 1470"><p>The Supplier shall carry sufficient inventories to assure ex-stock supply of consumable spare parts or components for the Goods for a period of <i>thirty (30) calendar days</i>.</p></div> <div data-bbox="324 1507 1511 1582"><p>Spare parts or components shall be supplied as promptly as possible, but in any case, within two (2) months of placing the order.</p></div> <div data-bbox="324 1619 492 1657"><p><b>Packaging –</b></p></div> <div data-bbox="324 1694 1511 1948"><p>The Supplier shall provide such packaging of the Goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in this Contract. The packaging shall be sufficient to withstand, without limitation, rough handling during transit and exposure to extreme temperatures, salt and precipitation during transit, and open storage. Packaging case size and weights shall take into consideration, where appropriate, the remoteness of the Goods’ final destination and the absence of heavy handling facilities at all points in transit.</p></div> <div data-bbox="324 1986 1511 2133"><p>The packaging, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract, including additional requirements, if any, specified below, and in any subsequent instructions ordered by the Procuring Entity.</p></div>
--	---





	<p>The outer packaging must be clearly marked on at least four (4) sides as follows:</p> <p>Name of the Procuring Entity Name of the Supplier Contract Description Final Destination Gross weight Any special lifting instructions Any special handling instructions Any relevant HAZCHEM classifications</p> <p>A packaging list identifying the contents and quantities of the package is to be placed on an accessible point of the outer packaging if practical. If not practical the packaging list is to be placed inside the outer packaging but outside the secondary packaging.</p> <p><b>Transportation –</b></p> <p>Where the Supplier is required under Contract to deliver the Goods CIF, CIP, or DDP, transport of the Goods to the port of destination or such other named place of destination in the Philippines, as shall be specified in this Contract, shall be arranged and paid for by the Supplier, and the cost thereof shall be included in the Contract Price.</p> <p>Where the Supplier is required under this Contract to transport the Goods to a specified place of destination within the Philippines, defined as the Project Site, transport to such place of destination in the Philippines, including insurance and storage, as shall be specified in this Contract, shall be arranged by the Supplier, and related costs shall be included in the contract price.</p> <p>Where the Supplier is required under Contract to deliver the Goods CIF, CIP or DDP, Goods are to be transported on carriers of Philippine registry. In the event that no carrier of Philippine registry is available, Goods may be shipped by a carrier which is not of Philippine registry provided that the Supplier obtains and presents to the Procuring Entity certification to this effect from the nearest Philippine consulate to the port of dispatch. In the event that carriers of Philippine registry are available but their schedule delays the Supplier in its performance of this Contract the period from when the Goods were first ready for shipment and the actual date of shipment the period of delay will be considered force majeure.</p> <p>The Procuring Entity accepts no liability for the damage of Goods during transit other than those prescribed by INCOTERMS for DDP deliveries. In the case of Goods supplied from within the Philippines or supplied by domestic Suppliers risk and title will not be deemed to have passed to the Procuring Entity until their receipt and final acceptance at the final destination.</p> <p><b>Intellectual Property Rights –</b></p> <p>The Supplier shall indemnify the Procuring Entity against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the Goods or any part thereof.</p> <p><b>PERFORMANCE &amp; TESTINGS –</b></p> <p>Site Inspection and Tests (Point of Delivery Performance &amp; Testing)</p> <p><b>Upon installation</b>, perform the necessary adjustments and calibrations to set the tolerance within the allowable and acceptable limits and in accordance with the standard manufacturer’s recommendations.</p>
--	--

	<p>The performance data of the completely delivered, installed and fully functional air – conditioning equipment must be inspected and tested, results must satisfactorily comply with the required contract specifications and approved product standards for the safety, quality, energy performance and commercial application.</p> <p>Tests results must be within the acceptable limits, and must be checked with cross references to the manufacturer’s standards and recommendations, production data sheets, and actual test results gathered during the final tests and commissioning of all equipment.</p> <p>All tests shall be witnessed by SSS authorized representative/s.</p>
2.2	<p>The terms of payment shall be one – time upon completion and acceptance of the project.</p> <p>The following requirements must also be complied with:</p> <ol style="list-style-type: none"> <li>1. Testing and inspection of the units;</li> <li>2. Submission of complete documents (Delivery Receipts, Sales Invoice, signed &amp; sealed As-built plans, Operation and Installation Manuals, Brochures, and Start-up test results and other documents required in the project.</li> <li>3. <b>Refrigerant pipes:</b> The first 10ft. is included in the initial installation cost.</li> </ol> <p>In case the total length of actual installed refrigerant pipes is either less or more than 10% of the given quantity in the Bill of Quantities, proportionate cost adjustment shall be applied as deductive and/or additive.</p> <p><b>Note: Applicable cost adjustment for this particular item shall be applied even without the necessary issuance of amendment to order.</b></p> <p>In case the total length of actual installed refrigerant pipes is within (+/-) 10% as compared with the given lengths in the Bill of Quantities, no cost adjustment shall be imposed.</p> <ol style="list-style-type: none"> <li>4. Issuance of Certificate of Completion and Acceptance by the implementing unit.</li> </ol> <p>Payment shall be credited to the LANDBANK or DBP or any choice of bank account subject to applicable bank charges of the winning bidder.</p> <p>The payment shall be subject to retention of Withholding Tax and other applicable taxes in accordance with existing Laws and BIR Rules and Regulations, to be remitted directly to the BIR by the SSS.</p> <p>Payment using Letter of Credit is not allowed.</p>
4	Not Applicable
5.1	<p><b>Warranty</b></p> <p>Warranty Period for all brand new air-conditioning units is <b>one (1) year</b> for parts and services. SEMI ANNUALLY service and maintenance shall be undertaken by the winning bidder within the warranty period.</p>
5.2	<p>Correction of defects in the warranty period shall be done <b><u>within three (3) days</u></b> after notification of defect was first communicated (verbally or in writing) by SSS to the Supplier.</p>





6	<p data-bbox="324 191 649 2282"><b>Liability of the Supplier</b></p> <p data-bbox="324 269 1511 705">1. <b>CONFIDENTIALITY.</b> Neither party shall, without the prior written consent of the other, disclose or make available to any person, make public, or use directly or indirectly, except for the performance and implementation of the works, any confidential information, acquired from an information holder in connection with the performance of this Contract, unless: (i) the information is known to the disclosing party, as evidenced by its written records, prior to obtaining the same from the information holder and is not otherwise subject to disclosure restrictions on the disclosing party, (ii) the information is disclosed to the disclosing party by a third party who did not receive the same, directly or indirectly, from an information holder, and who has no obligation of secrecy with respect thereto, or (iii) required to be disclosed by law. The obligation of confidentiality by both parties, as provided herein, shall survive the termination of the Agreement.</p> <p data-bbox="324 745 1511 924">2. <b>MERGER AND CONSOLIDATION.</b> In case of merger, consolidation or change of ownership of the SUPPLIER with other company, it is the responsibility of the surviving company/consolidated company/acquiring entity to inform SSS of the change in corporate structure/ownership. Failure to do so shall translate in such company assuming all liabilities of the acquired/merged company under the Agreement.</p> <p data-bbox="324 964 1511 1108">3. <b>FORCE MAJEURE.</b> SUPPLIER shall not be liable for forfeiture of its performance security, liquidated damages, or termination for default if and to the extent that SUPPLIER's delay in performance or other failure to perform its obligations under this Agreement is the result of a force majeure.</p> <p data-bbox="386 1148 1511 1440">For purposes of this Agreement the terms "force majeure" and "fortuitous event" may be used interchangeably. In this regard, a fortuitous event or force majeure shall be interpreted to mean an event which SUPPLIER could not have foreseen, or which though foreseen, was inevitable. It shall not include ordinary unfavorable weather conditions; and any other cause the effects of which could have been avoided with the exercise of reasonable diligence by SUPPLIER. Such events may include, but not limited to, acts of SSS in its sovereign capacity, wars or revolutions, fires, floods, epidemics, quarantine restrictions, and freight embargoes.</p> <p data-bbox="386 1480 1511 1659">If a force majeure situation arises, SUPPLIER shall promptly notify SSS in writing of such condition and the cause thereof. Unless otherwise directed by SSS in writing, SUPPLIER shall continue to perform its obligations under this Agreement as far as is reasonably practical and shall seek all reasonable alternative means for performance not prevented by the force majeure.</p> <p data-bbox="324 1699 1511 1844">4. <b>NON-ASSIGNMENT.</b> SUPPLIER shall not assign its rights or obligations under this Agreement, in whole or in part, except with SSS's prior written consent. SUPPLIER shall not subcontract in whole or in part the PROJECT and deliverables subject of this Agreement without the written consent of SSS.</p> <p data-bbox="324 1883 1511 2138">5. <b>WAIVER.</b> Failure by either party to insist upon the other strict performance of any of the terms and conditions hereof shall not be deemed a relinquishment or waiver of any subsequent breach or default of the terms and conditions hereof, which can only be deemed made if expressed in writing and signed by its duly authorized representative. No such waiver shall be construed as modification of any of the provisions of the Agreement or as a waiver of any past or future default or breach hereof, except as expressly stated in such waiver.</p>
---	---



	<p>6. CUMULATIVE REMEDIES. Any and all remedies granted to the parties under the applicable laws and the Contract shall be deemed cumulative and may therefore, at the sole option and discretion, be availed of by the aggrieved party simultaneously, successively, or independently.</p> <p>7. NO EMPLOYER-EMPLOYEE RELATIONSHIP. It is expressly and manifestly understood and agreed upon that the employees of SUPPLIER assigned to perform the PROJECT are not employees of SSS. Neither is there an employer-employee relationship between SSS and SUPPLIER.</p> <p>The Agreement does not create an employer-employee relationship between SSS and the SUPPLIER including its personnel; that the services rendered by the personnel assigned by SUPPLIER to SSS in the performance of its obligation under the contract do not represent government service and will not be credited as such; that its personnel assigned to SSS are not entitled to benefits enjoyed by SSS' officials and employees such as Personal Economic Relief Allowance (PERA), Representation and Transportation Allowance (RATA), ACA, etc.; that these personnel are not related within the third degree of consanguinity or affinity to the contracting officer and appointing authority of SSS; that they have not been previously dismissed from the government service by reason of an administrative case; that they have not reached the compulsory retirement age of sixty-five (65); and that they possess the education, experience and skills required to perform the job. The SUPPLIER hereby acknowledges that no authority has been given by SSS to hire any person as an employee of the latter. Any instruction given by SSS or any of its personnel to SUPPLIER's employees is to be construed merely as a measure taken by the former to ensure and enhance the quality of project performed hereunder. The SUPPLIER shall, at all times, exercise supervision and control over its employees in the performance of its obligations under the contract.</p> <p>8. PARTNERSHIP. Nothing in the contract shall constitute a partnership between the parties. No party or its agents or employees shall be deemed to be the agent, employee or representative of any other party.</p> <p>9. COMPLIANCE WITH SS LAW. SUPPLIER shall report all its employees to SSS for coverage and their contributions, as well as, all amortizations for salary/education/calamity and other SSS loans shall be updated. Should SUPPLIER fail to comply with its obligations under the provisions of the SS Law and Employees' Compensation Act, SSS shall have the authority to deduct any unpaid SS and EC contributions, salary, educational, emergency and/or calamity loan amortizations, employer's liability for damages, including interests and penalties from SUPPLIER's receivables under this Agreement.</p> <p>Further, prescription does not run against SSS for its failure to demand SS contributions or payments from SUPPLIER. Moreover, SUPPLIER shall forever hold in trust SS contributions or payments of its employees until the same is fully remitted to SSS.</p> <p>10. COMPLIANCE WITH LABOR LAWS. SUPPLIER, as employer of the personnel assigned to undertake the PROJECT, shall comply with all its obligations under existing laws and their implementing rules and regulations on the payment of minimum wage, overtime pay, and other labor-related benefits as well as remittances or payment of the appropriate amount or contributions/payment (SSS, EC, Pag-IBIG, PhilHealth and taxes) with concerned government agencies/offices.</p> <p>It is agreed further, that prior to the release of any payment by SSS to SUPPLIER, its President or its duly authorized representative, shall submit a sworn statement that all monies due to all its employees assigned to the PROJECT as well as benefits by law and other related labor legislation have been paid by SUPPLIER and that he/she assumed full responsibility thereof.</p>
--	--



	<p>11. <b>COMPLIANCE WITH TAX LAWS.</b> SUPPLIER shall, in compliance with tax laws, pay the applicable taxes in full and on time and shall regularly present to SSS within the duration of the Contract, tax clearance from the Bureau of Internal Revenue (BIR) as well as copy of its income and business tax returns duly stamped by the BIR and duly validated with the tax payments made thereon. Failure by SUPPLIER to comply with the foregoing shall entitle SSS to suspend payment of the Contract Price.</p> <p>As required under Executive Order (EO) 398, s. 2005, SUPPLIER shall submit income and business tax returns duly stamped and received by the BIR, before entering and during the duration of this Agreement. SUPPLIER, through its responsible officer, shall also certify under oath that it is free and clear of all tax liabilities to the government. SUPPLIER shall pay taxes in full and on time and that failure to do so will entitle SSS to suspend or terminate this Agreement.</p> <p>12. <b>LIQUIDATED DAMAGES.</b> If SUPPLIER fails to satisfactorily deliver any or all of the Goods and/or to perform the Services within the period(s) specified in the PBD inclusive of duly granted time extensions if any, SSS shall, without prejudice to its other remedies under this Agreement and under the applicable law, deduct from the Contract Price, as liquidated damages, the applicable rate of one tenth (1/10) of one (1) percent of the cost of the unperformed portion for every day of delay until actual delivery or performance. Once the amount of liquidated damages reaches ten percent (10%), SSS may rescind or terminate this Agreement, without prejudice to other courses of action and remedies open to it.</p> <p>13. <b>HOLD FREE and HARMLESS.</b> SUPPLIER agrees to defend, indemnify, and hold SSS free and harmless from any and all claims, damages, expenses, fines, penalties and/or liabilities of whatever nature and kind, whether in law or equity, that may arise by reason of the implementation of the Agreement. In addition, SUPPLIER agrees to indemnify SSS for any damage as a result of said implementation.</p> <p>SUPPLIER hereby assumes full responsibility for any injury, including death, loss or damage which may be caused to SSS' employees or property or third person due to SUPPLIER's employees' fault or negligence, and further binds itself to hold SSS free and harmless from any of such injury or damage. SSS shall not be responsible for any injury, loss or damage which SUPPLIER or any of its employees may sustain in the performance of SUPPLIER's obligations under this Agreement.</p> <p>14. <b>SETTLEMENT OF DISPUTES.</b> If any dispute or difference of any kind whatsoever shall arise between SSS and SUPPLIER in connection with or arising out of this Agreement, the Parties shall make every effort to resolve amicably such dispute or difference by mutual consultation.</p> <p>If after thirty (30) days, the Parties have failed to resolve their dispute or difference by such mutual consultation, then either SSS or SUPPLIER may give notice to the other Party of its intention to commence arbitration, in accordance with RA No. 876, otherwise known as the "Arbitration Law" and RA No. 9285, otherwise known as the "Alternative Dispute Resolution Act of 2004," in order to settle their disputes.</p> <p>No arbitration in respect of this matter may be commenced unless such notice is given.</p> <p>Notwithstanding any reference to arbitration herein, the Parties shall continue to perform their respective obligations under this Agreement unless they otherwise agree.</p> <p>15. <b>VENUE OF ACTIONS.</b> In the event court action is necessary in order to promote Arbitration, such action shall be filed only before the proper courts of Quezon City, to the exclusion of all other venues.</p>
--	---



	<p>16. <b>GOVERNING LAW.</b> The Agreement shall be governed by and interpreted according to the laws of the Republic of the Philippines.</p> <p>17. <b>AMENDMENTS.</b> This Agreement may be amended only in writing and executed by the parties or their duly authorized representatives.</p> <p>18. <b>SEPARABILITY.</b> If any one or more of the provisions contained in the contract or any document executed in connection herewith shall be invalid, illegal or unenforceable in any respect under any applicable law, then: (i) the validity, legality and enforceability of the remaining provisions contained herein or therein shall not in any way be affected or impaired and shall remain in full force and effect; and (ii) the invalid, illegal or unenforceable provision shall be replaced by the parties immediately with a term or provision that is valid, legal and enforceable and that comes closest to expressing the intention of such invalid illegal or unenforceable term of provision.</p> <p>19. <b>BINDING EFFECT.</b> The Agreement shall be binding upon the Parties hereto, their assignee/s and successor/s-in-interest.</p>
--	---



*Section VI. Schedule of Requirements*

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item No.	Description	Quantity	Delivered, Weeks/Months
1.	SUPPLY, DELIVERY AND INSTALLATION OF TWELVE (12) AIR-CONDITIONING UNITS AT THE PROPOSED RELOCATION SITE OF SSS CALBAYOG BRANCH OFFICE	12 units	30 calendar days upon receipt of Notice to Proceed and Signed Contract
2.	SUPPLY, DELIVERY AND INSTALLATION OF SEVEN (7) AIR-CONDITIONING UNITS AT THE PROPOSED RELOCATION SITE OF SSS DAVAO – ILUSTRE BRANCH OFFICE	7 units	30 calendar days upon receipt of Notice to Proceed and Signed Contract

Name: \_\_\_\_\_

Legal capacity: \_\_\_\_\_

Signature: \_\_\_\_\_

Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_

Date: \_\_\_\_\_



*Section VII. Technical Specifications*

A handwritten signature in blue ink, consisting of stylized, cursive letters.

Technical Specifications

Item	Specification	Statement of Compliance	Annex
<p><i>Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. <b>Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence.</b> Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. <b>A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection.</b> A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.</i></p>			
<p><b>Lot 1: Supply, Delivery and Installation of Twelve (12) Air-Conditioning Units at the Proposed Relocation Site of Calbayog Branch</b></p>			
<p><b>A. Mechanical Works and Equipment</b></p> <p>All Mechanical Works shall be done in accordance with the Standard Manufacturer’s recommendation for the material specification and workmanship execution.</p> <p><i>All Air – Conditioner brochures submitted as supporting documents must be verifiable in manufacturer’s official website.</i></p>			
<p><b>1. Mechanical Equipment</b></p>			
a. 3TR/4HP Ceiling Mounted/ Suspended Inverter Split – type (can offer unit with capacity of 3TR or 4HP)	Ceiling Mounted/Suspended, Inverter, Split Type AC Nominal Cooling Capacity (min – max): 10.0kW (5.0 – 11.2kW) Refrigerant: R – 32 Power Consumption: 3.2 – 3.3 kW Electrical Data: 230V, Single Phase, 60Hz COP/EER: 3.09 (minimum) Can accommodate 50 meters piping length		
b. 3TR/4HP Floor Mounted Inverter Split – type (can offer unit with capacity of 3TR or 4HP)	Floor Mounted, Inverter, Split Type AC Nominal Cooling Capacity (min – max): 10.0kW (5.0 – 11.2kW) Refrigerant: R – 32 Power Consumption: 3.5 – 3.6 kW Electrical Data: 230V, Single Phase, 60Hz COP/EER: 2.79 (minimum) Can accommodate 50 meters piping length		
c. 2.5HP Wall Mounted Inverter Split – type	Wall Mounted, Inverter, Split Type AC Nominal Cooling Capacity (min – max): 6.0kW (1.2 – 7.1kW) Refrigerant: R – 32 Power Consumption: 1.5 - 1.7kW Electrical Data: 230V, Single Phase, 60Hz		

Item	Specification	Statement of Compliance	Annex
	COP/EER: 3.75 (minimum) Can accommodate 30 meters piping length		
d. 2HP Wall Mounted Inverter Split – type	Wall Mounted, Inverter, Split Type AC Nominal Cooling Capacity (min – max): 5.2kW (1.2 – 6.2kW) Refrigerant: R – 32 Power Consumption: 1.3 – 1.4kW Electrical Data: 230V, Single Phase, 60Hz COP/EER: 3.94 (minimum) Can accommodate 30 meters piping length		
<b>2. Pipes and Fittings</b> Refer to manufacturer’s recommendations for pipes and fittings size requirement	Hard-drawn Copper Tube for all Split-type air-conditioning system		
<b>3. Wires/Cables</b>  a. 3.5mm <sup>2</sup> , 5.5mm <sup>2</sup>  b. Royal Cord	THHN/THWN stranded wire PVC insulated, nylon jacketed, Moisture and Heat Resistant, 600V, 90°C max. operating temperature, Lead-free  4-core, #14		
<b>4. Circuit Breakers/ Panel</b>  Enclosed Circuit Breaker	For 3TR/4HP: 40A, 2P, 230V, 60Hz, 20kAIC, Bolt-on, Industrial type, Surface Mounted, NEMA3R Enclosure  For 2.5HP and 2HP: 30A, 2P, 230V, 60Hz, 20kAIC, Bolt-on, Industrial type, Surface Mounted, NEMA3R Enclosure		

Name: \_\_\_\_\_

Legal capacity: \_\_\_\_\_

Signature: \_\_\_\_\_

Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_

Date: \_\_\_\_\_





Item	Specification	Statement of Compliance	Annex
<p><i>Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. <b>Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence.</b> Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. <b>A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection.</b> A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.</i></p>			
<p><b>Lot 2: Supply, Delivery and Installation of Seven (7) Air-Conditioning Units at the Proposed Relocation Site of Davao – Ilustre Branch</b></p>			
<p><b>A. Mechanical Works and Equipment</b></p> <p>All Mechanical Works shall be done in accordance with the Standard Manufacturer’s recommendation for the material specification and workmanship execution.</p> <p><i>All Air – Conditioner brochures submitted as supporting documents must be verifiable in manufacturer’s official website.</i></p>			
<p><b>1. Mechanical Equipment</b></p>			
a. 3TR/4HP Ceiling Mounted/ Suspended Inverter Split – type (can offer unit with capacity of 3TR or 4HP)	Ceiling Mounted/Suspended, Inverter, Split Type AC Nominal Cooling Capacity (min – max): 10.0kW (5.0 – 11.2kW) Refrigerant: R – 32 Power Consumption: 3.2 – 3.3 kW Electrical Data: 230V, Single Phase, 60Hz COP/EER: 3.09 (minimum) Can accommodate 50 meters piping length		
b. 3TR/4HP Floor Mounted Inverter Split – type (can offer unit with capacity of 3TR or 4HP)	Floor Mounted, Inverter, Split Type AC Nominal Cooling Capacity (min – max): 10.0kW (5.0 – 11.2kW) Refrigerant: R – 32 Power Consumption: 3.5 – 3.6 kW Electrical Data: 230V, Single Phase, 60Hz COP/EER: 2.79 (minimum) Can accommodate 50 meters piping length		
c. 2HP Wall Mounted Inverter Split – type	Wall Mounted, Inverter, Split Type AC Nominal Cooling Capacity (min – max): 5.2kW (1.2 – 6.2kW) Refrigerant: R – 32 Power Consumption: 1.3 – 1.4kW Electrical Data: 230V, Single Phase, 60Hz COP/EER: 3.94 (minimum) Can accommodate 30 meters piping length		
d. 2HP Window Type Inverter RAC	Window Type Inverter Room Air – Conditioner with wireless remote control Cooling Capacity: 5.21kW Refrigerant: R – 32		



Item	Specification	Statement of Compliance	Annex
	Power Consumption: 1.50 – 1.60 kW EER: 12 kJ/Hr – W Electrical Data: 230V, single phase, 60Hz		
<b>2. Pipes and Fittings</b> Refer to manufacturer’s recommendations for pipes and fittings size requirement	Hard-drawn Copper Tube for all Split-type air-conditioning system		
<b>3. Wires/Cables</b> a. 3.5mm <sup>2</sup> , 5.5mm <sup>2</sup>  b. Royal Cord	THHN/THWN stranded wire PVC insulated, nylon jacketed, Moisture and Heat Resistant, 600V, 90°C max. operating temperature, Lead-free  4-core, #14		
<b>4. Circuit Breakers/ Panel</b> Enclosed Circuit Breaker	For 3TR/4HP: 40A, 2P, 230V, 60Hz, 20kAIC, Bolt-on, Industrial type, Surface Mounted, NEMA3R Enclosure  For 2HP: 30A, 2P, 230V, 60Hz, 20kAIC, Bolt-on, Industrial type, Surface Mounted, NEMA3R Enclosure		

Name: \_\_\_\_\_

Legal capacity: \_\_\_\_\_

Signature: \_\_\_\_\_

Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_

Date: \_\_\_\_\_



***Section VIII. Checklist of Technical and  
Financial Documents***

## CHECKLIST OF TECHNICAL AND FINANCIAL DOCUMENTS

### I. TECHNICAL COMPONENT ENVELOPE

#### *Class “A” Documents*

##### Legal Documents

- ☐ (a) Valid PhilGEPS Certificate of Platinum Registration and Membership (Platinum Membership) (all pages);

##### Technical Documents

- ☐ (b) Statement of the prospective bidder of all its ongoing government and private contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid; **and**
- ☐ (c) Statement of the bidder’s Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided for in Sections 23.4.1.3 and 23.4.2.4 of the 2016 revised IRR of RA No. 9184, within five (5) year period prior to the submission and opening of Bids; **and**
- ☐ (d) Original copy of Bid Security (Cash, Letter of Credit, Surety Bond). If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission; **Or** Original copy of Notarized Bid Securing Declaration; **and**
- ☐ (e) Conformity with the Schedule of Requirements (Section VI) and Technical Specifications (Section VII), which may include production/delivery schedule, manpower requirements, and/or after-sales/parts, if applicable; **and**
- ☐ (f) Original duly signed Omnibus Sworn Statement (OSS); **and** if applicable, Original Notarized Secretary’s Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder.

##### Other documentary requirements under RA No. 9184 (as applicable)

For foreign bidders claiming by reason of their country’s extension of reciprocal rights to Filipinos:

- ☐ (g) Copy of Treaty, International or Executive Agreement; **or**
- ☐ (h) Certification from the relevant government office of their country stating that Filipinos are allowed to participate in government procurement activities for the same item or product.
- ☐ (i) Certification from the DTI if the Bidder claims preference as a Domestic Bidder or Domestic Entity.

#### *Class “B” Documents*

- ☐ (j) If applicable, a duly signed joint venture agreement (JVA) in case the joint venture is already in existence;  
**or**  
duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.

### Financial Documents

- ☐ (k) The Supplier's audited financial statements, showing, among others, the Supplier's total and current assets and liabilities, stamped "received" by the BIR or its duly accredited and authorized institutions, for the preceding calendar year which should not be earlier than two (2) years from the date of bid submission; **and**
- ☐ (l) The prospective bidder's computation of Net Financial Contracting Capacity (NFCC);  
**or**  
A committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation.

### **II. FINANCIAL COMPONENT ENVELOPE**

- ☐ (m) Original of duly signed and accomplished Financial Bid Form; **and**
- ☐ (n) Original of duly signed and accomplished Price Schedule(s)/Bid Breakdown.

### **IMPORTANT REMINDERS**

- A) Each and every page of the **Bid Forms/Price Schedule(s)/Bid Breakdown**, under Section VIII: Checklist of Technical and Financial Documents hereof, shall be signed by the duly authorized representative/s of the Bidder. Failure to do so shall be a ground for the rejection of the bid.
- B) Any interlineations, erasures, or overwriting shall be valid only if they are signed or initialed by the duly authorized representative/s of the Bidder.
- C) Bid documents shall be compiled in a folder/binder with the Annexes properly labeled with tabs/separators.
- D) Bidders shall submit their bids through their duly authorized representative enclosed in separate sealed envelopes, which shall be submitted simultaneously:
  - a) The first three individually sealed envelopes shall contain the folder/binder of the Eligibility Requirements and Technical Component of the bid; prepared in three copies labeled as follows:  
  
Envelop (1): ORIGINAL – Eligibility Requirements and Technical Component  
Envelop (2): COPY1 – Eligibility Requirements and Technical Component  
Envelop (3): COPY2 – Eligibility Requirements and Technical Component
  - b) The next three individually sealed envelopes shall contain the folder/binder of the Financial Component of the bid; prepared in three copies labeled as follows:  
  
Envelop (4): ORIGINAL – Financial Component  
Envelop (5): COPY1 – Financial Component  
Envelop (6): COPY2 – Financial Component
  - c) Bidders shall enclose, seal and mark the following:  
  
Envelop (7): Envelope (1) and Envelope (4) enclosed in one sealed envelope marked "ORIGINAL-BID"

Envelop (8): Envelope (2) and Envelope (5) enclosed in one sealed envelope marked “COPY1–BID”

Envelop (9): Envelope (3) and Envelope (6) enclosed in one sealed envelope marked “COPY2–BID”

- d) Envelopes (7) to (9) shall then be enclosed in a single sealed, signed final/outerenvelope/package/box
- e) All envelopes (Envelopes (1) to (9) and the final/outer envelope/package/box) shall indicate the following:
  - addressed to the Procuring Entity’s BAC
  - name and address of the Bidder in capital letters
  - name of the contract/project to be bid in capital letters
  - bear the specific identification/reference code of this bidding process
  - bear a warning “DO NOT OPEN BEFORE...” the date and time for the opening of bids

**THE CHAIRPERSON**  
**BIDS AND AWARDS COMMITTEE**  
**2<sup>ND</sup> FLOOR, SSS MAIN BUILDING**  
**EAST AVENUE, DILIMAN, QUEZON CITY**

NAME OF BIDDER : \_\_\_\_\_  
ADDRESS : \_\_\_\_\_

NAME OF PROJECT: \_\_\_\_\_  
ITB REFERENCE NUMBER: \_\_\_\_\_

DO NOT OPEN BEFORE  
(the date and time for the opening of bids)

- E) Bids submitted after the deadline shall only be marked for recording purpose, shall not be included in the opening of bids, and shall be returned to the bidder unopened.



FORMS

FORM-01



Bid Form for the Procurement of Goods

BID FORM

Lot 1: Supply, Delivery and Installation of Twelve (12) Air-Conditioning Units at the Proposed Relocation Site of Calbayog Branch

Date: \_\_\_\_\_  
Project Identification No.: \_\_\_\_\_

To: **SOCIAL SECURITY SYSTEM**  
East Avenue, Diliman, Quezon City

Having examined the Philippine Bidding Documents (PBDs) including the Supplemental or Bid Bulletin Numbers [insert numbers], the receipt of which is hereby duly acknowledged, we, the undersigned, offer to Supply, Delivery and Installation of Twelve (12) Air-Conditioning Units at the Proposed Relocation Site of Calbayog Branch in conformity with the said PBDs for the sum of [**total Bid amount in words and figures**] or the total calculated bid price, as evaluated and corrected for computational errors, and other bid modifications in accordance with the Price Schedules/Bid Breakdown attached herewith and made part of this Bid. The total bid price includes the cost of all taxes, such as, but not limited to: [specify the applicable taxes, e.g. (i) value added tax (VAT), (ii) income tax, (iii) local taxes, and (iv) other fiscal levies and duties], which are itemized herein or in the Price Schedules/Bid Breakdown,

If our Bid is accepted, we undertake:

- a. to deliver the goods in accordance with the delivery schedule specified in the Schedule of Requirements of the Philippine Bidding Documents (PBDs);
- b. to provide a performance security in the form, amounts, and within the times prescribed in the PBDs;
- c. to abide by the Bid Validity Period specified in the PBDs and it shall remain binding upon us at any time before the expiration of that period.

[Insert this paragraph if Foreign-Assisted Project with the Development Partner:

Commissions or gratuities, if any, paid or to be paid by us to agents relating to this Bid, and to contract execution if we are awarded the contract, are listed below:

Name and address of agent	Amount and Purpose of Commission or gratuity
_____	_____
_____	_____
_____	_____

(if none, state “None”)

Until a formal Contract is prepared and executed, this Bid, together with your written acceptance thereof and your Notice of Award, shall be binding upon us.

We understand that you are not bound to accept the Lowest Calculated Bid or any Bid you may receive.

We certify/confirm that we comply with the eligibility requirements pursuant to the PBDs.





The undersigned is authorized to submit the bid on behalf of [name of the bidder] as evidenced by the attached [state the written authority].

We acknowledge that failure to sign each and every page of this Bid Form, including the attached Schedule of Prices/Bid Breakdown, shall be a ground for the rejection of our bid.

Name: \_\_\_\_\_

Legal capacity:\_\_\_\_\_

Signature:\_\_\_\_\_

Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_

Date: \_\_\_\_\_



Bid Form for the Procurement of Goods

BID FORM

Lot 2: Supply, Delivery and Installation of Seven (7) Air-Conditioning Units at the Proposed Relocation Site of Davao – Ilustre Branch

Date: \_\_\_\_\_  
Project Identification No.: \_\_\_\_\_

To: **SOCIAL SECURITY SYSTEM**  
East Avenue, Diliman, Quezon City

Having examined the Philippine Bidding Documents (PBDs) including the Supplemental or Bid Bulletin Numbers [insert numbers], the receipt of which is hereby duly acknowledged, we, the undersigned, offer to Supply, Delivery and Installation of Seven (7) Air-Conditioning Units at the Proposed Davao – Ilustre Branch in conformity with the said PBDs for the sum of [**total Bid amount in words and figures**] or the total calculated bid price, as evaluated and corrected for computational errors, and other bid modifications in accordance with the Price Schedules/Bid Breakdown attached herewith and made part of this Bid. The total bid price includes the cost of all taxes, such as, but not limited to: [specify the applicable taxes, e.g. (i) value added tax (VAT), (ii) income tax, (iii) local taxes, and (iv) other fiscal levies and duties], which are itemized herein or in the Price Schedules/Bid Breakdown,  
If our Bid is accepted, we undertake:

- a. to deliver the goods in accordance with the delivery schedule specified in the Schedule of Requirements of the Philippine Bidding Documents (PBDs);
- b. to provide a performance security in the form, amounts, and within the times prescribed in the PBDs;
- c. to abide by the Bid Validity Period specified in the PBDs and it shall remain binding upon us at any time before the expiration of that period.

[Insert this paragraph if Foreign-Assisted Project with the Development Partner:

Commissions or gratuities, if any, paid or to be paid by us to agents relating to this Bid, and to contract execution if we are awarded the contract, are listed below:

Name and address of agent	Amount and Purpose of Commission or gratuity
_____	_____
_____	_____
_____	_____

(if none, state “None”)

Until a formal Contract is prepared and executed, this Bid, together with your written acceptance thereof and your Notice of Award, shall be binding upon us.

We understand that you are not bound to accept the Lowest Calculated Bid or any Bid you may receive.

We certify/confirm that we comply with the eligibility requirements pursuant to the PBDs.

The undersigned is authorized to submit the bid on behalf of [name of the bidder] as evidenced by the attached [state the written authority].



We acknowledge that failure to sign each and every page of this Bid Form, including the attached Schedule of Prices/Bid Breakdown, shall be a ground for the rejection of our bid.

Name: \_\_\_\_\_

Legal capacity:\_\_\_\_\_

Signature:\_\_\_\_\_

Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_

Date: \_\_\_\_\_

**FORM-02**

**Price Schedule(s)/Bid Breakdown**

---



**Lot 1: Supply, Delivery and Installation of Twelve (12) Air-Conditioning Units at the  
Proposed Relocation Site of Calbayog Branch**

Name of Bidder

Invitation to Bid Number

Cost Component	Qty/Unit	Cost per Unit	Total Cost
<p>I. Supply, Delivery and Installation of Brand New 3TR/4HP Ceiling Mounted/Suspended Inverter Split Type Air – Conditioner with Horizontal Discharge Air – Cooled Condensing Unit complete with standard accessories, electrical components and enclosed circuit breakers (ECB)</p> <p>Locations and approximate distances from FCU's to ACCU's:</p> <ul style="list-style-type: none"> <li>- ACU 101 at Administrative Section FCU to ACCU: 17.61 meters</li> <li>- ACU 102 at Accounts Management Section FCU to ACCU: 17.61 meters</li> <li>- ACU 103 at Medical Evaluation Center FCU to ACCU: 10.47 meters</li> </ul>	3 sets	₱	₱
<p>II. Supply, Delivery and Installation of Brand New 3TR Floor Mounted Split Type Air – Conditioner with Horizontal Discharge Air – Cooled Condensing Unit complete with standard accessories, electrical components and enclosed circuit breakers (ECB)</p> <p>Locations and approximate distances from FCU's to ACCU's:</p> <ul style="list-style-type: none"> <li>- ACU 104 at Info Counter and PACD FCU to ACCU: 23.33 meters</li> <li>- ACU 105 at MSS Seating Area FCU to ACCU: 24.14 meters</li> <li>- ACU 106 at MSS Seating Area FCU to ACCU: 23.30 meters</li> <li>- ACU 107 at MSS Backroom FCU to ACCU: 16.61 meters</li> <li>- ACU 108 at e – Center FCU to ACCU: 15.31 meters</li> </ul>	5 sets	₱	₱
<p>III. Supply, Delivery and Installation of Brand New 2.5HP Wall Mounted Split Type Air – Conditioner with Horizontal Discharge Air – Cooled Condensing Unit complete with standard accessories, electrical components and enclosed circuit breakers (ECB) at the Teller Section (ACU 109)</p> <p>FCU to ACCU: 15.66 meters</p>	1 set	₱	₱
<p>IV. Supply, Delivery and Installation of Brand New 2HP Wall Mounted Split Type Air – Conditioner with Horizontal Discharge Air – Cooled Condensing Unit complete with standard accessories, electrical</p>	3 sets	₱	₱



Cost Component	Qty/Unit	Cost per Unit	Total Cost
components and enclosed circuit breakers (ECB) at the Teller Section (ACU 204)  Locations and approximate distances from FCU's to ACCU's:  - ACU 110 at Office of the Branch Head FCU to ACCU: 21.58 meters - ACU 111 at Conference Room FCU to ACCU: 21.72 meters - ACU 111 at ID Capture FCU to ACCU: 8.19 meters			
TOTAL	₱		

Kindly refer to Section V. Special Conditions of Contract under GCC Clause item 1 for General Conditions and Scope of Works. See drawing for other details.

Note:

- Any bid exceeding the ABC of ₱ 2,151,795.00 shall not be accepted.
- Fill up all required items/field in the bid breakdown. Failure to indicate any of the following shall mean outright disqualification since bid is considered Non-Responsive.
  - If the item is given for free, indicate dash (-), zero (0) or free
  - If the item is not applicable, indicate N/A
- Please use the softcopy of the Bid Breakdown provided to the bidders.
- All documents shall be signed, and each and every page thereof shall be initialed, by the duly authorized representative/s of the Bidder.
- Bid proposal must be inclusive of all applicable taxes.
- Warranty requirement is at no cost to SSS.

Name: \_\_\_\_\_

Legal capacity:\_\_\_\_\_

Signature:\_\_\_\_\_

Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_

FORM-02-A

Price Schedule(s)/Bid Breakdown



**Lot 2: Supply, Delivery and Installation of Seven (7) Air-Conditioning Units at the Proposed Relocation Site of Davao – Ilustre Branch**

Name of Bidder

Invitation to Bid Number

Cost Component	Qty/Unit	Cost per Unit	Total Cost
<p>I. Supply, Delivery and Installation of Brand New 3TR/4HP Ceiling Mounted/Suspended Inverter Split Type Air – Conditioner with Horizontal Discharge Air – Cooled Condensing Unit complete with standard accessories, electrical components and enclosed circuit breakers (ECB)</p> <p>Locations and approximate distances from FCU's to ACCU's:</p> <ul style="list-style-type: none"> <li>- ACU 101 at AMS and MSS Backroom FCU to ACCU: 21.42 meters</li> <li>- ACU 102 at AMS and MSS Counters FCU to ACCU: 18.86 meters</li> <li>- ACU 103 at Administrative Section FCU to ACCU: 12.47 meters</li> </ul>	3 sets	₱	₱
<p>II. Supply, Delivery and Installation of Brand New 3TR/4HP Floor Mounted Inverter Split Type Air – Conditioner with Horizontal Discharge Air – Cooled Condensing Unit complete with standard accessories, electrical components and enclosed circuit breakers (ECB) at Future Large Accounts Area (ACU 106)</p> <p>FCU to ACCU: 25.09 meters</p>	1 set	₱	₱
<p>III. Supply, Delivery and Installation of Brand New 2HP Wall Mounted Inverter Split Type Air – Conditioner with Horizontal Discharge Air – Cooled Condensing Unit complete with standard accessories, electrical components and enclosed circuit breakers (ECB)</p> <p>Locations and approximate distances from FCU's to ACCU's:</p> <ul style="list-style-type: none"> <li>- ACU 107 at Office of the Branch Head FCU to ACCU: 13.20 meters</li> <li>- ACU 108 at Conference Room FCU to ACCU: 14.55 meters</li> </ul>	2 sets	₱	₱
<p>IV. Supply, Delivery &amp; Installation of Brand New 2HP Window Type Inverter Room Air – Conditioner at Electrical Room (RAC 101)</p>	1 set	₱	₱
<b>TOTAL</b>	₱		

Kindly refer to Section V. Special Conditions of Contract under GCC Clause item 1 for General Conditions and Scope of Works. See drawing for other details.



**Note:**

- 7. Any bid exceeding the ABC of **₱ 1,125,360.00** shall not be accepted.
- 8. Fill up all required items/field in the bid breakdown. Failure to indicate any of the following shall mean outright disqualification since bid is considered Non-Responsive.
  - If the item is given for free, indicate dash (-), zero (0) or free
  - If the item is not applicable, indicate N/A
- 9. Please use the softcopy of the Bid Breakdown provided to the bidders.
- 10. All documents shall be signed, and each and every page thereof shall be initialed, by the duly authorized representative/s of the Bidder.
- 11. Bid proposal must be inclusive of all applicable taxes.
- 12. Warranty requirement is at no cost to SSS.

Name: \_\_\_\_\_

Legal capacity:\_\_\_\_\_

Signature:\_\_\_\_\_

Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_



YEAR	CURRENT ASSETS	CURRENT LIABILITIES
TOTAL		

CONTRACT DESCRIPTION	TOTAL CONTRACT AMOUNT AT AWARD	PERCENTAGE OF PLANNED AND ACTUAL ACCOMPLISHMENT	ESTIMATED COMPLETION TIME
TOTAL			

$$15 \quad \left( \frac{\text{Current Assets}}{\text{Current Assets}} - \frac{\text{Current Liabilities}}{\text{Current Liabilities}} \right) - \frac{\text{Total Outstanding Works}}{\text{Total Outstanding Works}} = \frac{\text{NFCC}}{\text{NFCC}}$$

**P** \_\_\_\_\_  
**NFCC**



**COMMITTED LINE OF CREDIT CERTIFICATE**

Date: \_\_\_\_\_

**Social Security System (SSS)**  
SSS Main Building, East Avenue  
Diliman, Quezon City

CONTRACT PROJECT	:	_____
COMPANY/FIRM	:	_____
ADDRESS	:	_____
BANK/FINANCING	:	_____
INSTITUTION	:	_____
ADDRESS	:	_____
AMOUNT	:	_____

This is to certify that the above Bank/Financing Institution with business address indicated above, commits to provide the (Supplier/Distributor/Manufacturer/Contractor), if awarded the above-mentioned Contract, a credit line in the amount specified above which shall be exclusively used to finance the performance of the above-mentioned contract subject to our terms, conditions and requirements.

The credit line shall be available within fifteen (15) calendar days after receipt by the (Supplier/Distributor/Manufacturer/Contractor) of the Notice of Award and such line of credit shall be maintained until issuance of Certificate of Acceptance by the Social Security System.

This Certification is being issued in favor of said (Supplier/Distributor/Manufacturer/Contractor) in connection with the bidding requirement of (Name of Procuring Entity) for the above-mentioned Contract. We are aware that any false statements issued by us make us liable for perjury.

The committed line of credit cannot be terminated or cancelled without the prior written approval of Social Security System.

\_\_\_\_\_  
Name and Signature of Authorized Financing Institution Office

\_\_\_\_\_  
Office Designation

Concurred by:

\_\_\_\_\_  
Name & Signature of (Supplier/Distributor/Manufacturer/Contractor) Authorized Representative  
\_\_\_\_\_  
Official Designation

SUBSCRIBED AND SWORN TO BEFORE ME this \_\_\_\_\_ day of \_\_\_\_\_ at \_\_\_\_\_  
Philippines, Affiant exhibited to me his/her competent Evidence of Identity (as defines by the 2004  
Rules on Notarial Practice \_\_\_\_\_ issued on \_\_\_\_\_ at \_\_\_\_\_, Philippines.

NOTARY PUBLIC

Doc No. : \_\_\_\_\_  
Page No. : \_\_\_\_\_  
Book No. : \_\_\_\_\_  
Series of : \_\_\_\_\_

(Note: The amount committed should be machine validated in the Certificate itself)



**FORM-05**

**STATEMENT OF ON-GOING GOVERNMENT AND PRIVATE CONTRACTS**

NAME OF CONTRACT	DATE OF CONTRACT	CONTRACT DURATION	OWNER’S NAME, ADDRESS, CONTACT NUMBERS AND E-MAIL ADDRESS	KINDS OF GOODS	AMOUNT OF CONTRACT	VALUE OF OUTSTANDING CONTRACT	REMARKS (Indicate “With NDA” or “Without NDA”)

**NOTE: INCLUDING PROJECTS WITH NON-DISCLOSURE AGREEMENT (NDA)**



STATEMENT OF SINGLE LARGEST COMPLETED CONTRACT SIMILAR TO  
THE PROJECT TO BE BID EQUIVALENT TO AT LEAST 50% OF THE ABC  
WITH ATTACHED CERTIFICATE OF FINAL COMPLETION

Lot 1: Supply, Delivery and Installation of Twelve (12) Air-Conditioning Units at the  
Proposed Relocation Site of Calbayog Branch

NAME OF CONTRACT	CONTRACT TERM	AMOUNT OF CONTRACT	CONTACT PERSON, CONTACT NO., ADDRESS, AND EMAIL ADDRESS

NOTE: SLCC SHOULD BE PROJECTS WITHOUT NON-DISCLOSURE  
AGREEMENT (NDA)



**FORM-06-A**

**STATEMENT OF SINGLE LARGEST COMPLETED CONTRACT SIMILAR TO  
THE PROJECT TO BE BID EQUIVALENT TO AT LEAST 50% OF THE ABC  
WITH ATTACHED CERTIFICATE OF FINAL COMPLETION**

**Lot 2: Supply, Delivery and Installation of Seven (7) Air-Conditioning Units at the  
Proposed Relocation Site of Davao – Ilustre Branch**

NAME OF CONTRACT	CONTRACT TERM	AMOUNT OF CONTRACT	CONTACT PERSON, CONTACT NO., ADDRESS, AND EMAIL ADDRESS

**NOTE: SLCC SHOULD BE PROJECTS WITHOUT NON-DISCLOSURE  
AGREEMENT (NDA)**



**Bid Securing Declaration Form**

**Lot 1: Supply, Delivery and Installation of Twelve (12) Air-Conditioning Units at the  
Proposed Relocation Site of Calbayog Branch**

REPUBLIC OF THE PHILIPPINES) CITY OF  
\_\_\_\_\_) S.S.

**BID SECURING DECLARATION**

**Project Identification No.: [Insert number]**

To: *[Insert name and address of the Procuring Entity]*

I/We, the undersigned, declare that:

1. I/We understand that, according to your conditions, bids must be supported by a Bid Security, which may be in the form of a Bid Securing Declaration.
2. I/We accept that: (a) I/we will be automatically disqualified from bidding for any procurement contract with any procuring entity for a period of two (2) years upon receipt of your Blacklisting Order; and, (b) I/we will pay the applicable fine provided under Section 6 of the Guidelines on the Use of Bid Securing Declaration, within fifteen (15) days from receipt of the written demand by the procuring entity for the commission of acts resulting to the enforcement of the bid securing declaration under Sections 23.1(b), 34.2, 40.1 and 69.1, except 69.1(f), of the IRR of RA No. 9184; without prejudice to other legal action the government may undertake.
3. I/We understand that this Bid Securing Declaration shall cease to be valid on the following circumstances:
  - a. Upon expiration of the bid validity period, or any extension thereof pursuant to your request;
  - b. I am/we are declared ineligible or post-disqualified upon receipt of your notice to such effect, and (i) I/we failed to timely file a request for reconsideration or (ii) I/we filed a waiver to avail of said right; and
  - c. I am/we are declared the bidder with the Lowest Calculated Responsive Bid, and I/we have furnished the performance security and signed the Contract.

IN WITNESS WHEREOF, I/We have hereunto set my/our hand/s this \_\_\_\_ day of *[month]*  
*[year]* at *[place of execution]*.

*[Insert NAME OF BIDDER OR ITS AUTHORIZED  
REPRESENTATIVE]*  
*[Insert signatory's legal capacity]* Affiant

**[Jurat]**

*[Format shall be based on the latest Rules on Notarial Practice]*

*GPPB Resolution No. 16-2020, dated 16 September 2020*

**Bid Securing Declaration Form**

**Lot 2: Supply, Delivery and Installation of Seven (7) Air-Conditioning Units at the  
Proposed Relocation Site of Davao – Ilustre Branch**

REPUBLIC OF THE PHILIPPINES) CITY OF  
\_\_\_\_\_) S.S.

**BID SECURING DECLARATION**

**Project Identification No.: *[Insert number]***

To: *[Insert name and address of the Procuring Entity]*

I/We, the undersigned, declare that:

4. I/We understand that, according to your conditions, bids must be supported by a Bid Security, which may be in the form of a Bid Securing Declaration.
5. I/We accept that: (a) I/we will be automatically disqualified from bidding for any procurement contract with any procuring entity for a period of two (2) years upon receipt of your Blacklisting Order; and, (b) I/we will pay the applicable fine provided under Section 6 of the Guidelines on the Use of Bid Securing Declaration, within fifteen (15) days from receipt of the written demand by the procuring entity for the commission of acts resulting to the enforcement of the bid securing declaration under Sections 23.1(b), 34.2, 40.1 and 69.1, except 69.1(f), of the IRR of RA No. 9184; without prejudice to other legal action the government may undertake.
6. I/We understand that this Bid Securing Declaration shall cease to be valid on the following circumstances:
  - d. Upon expiration of the bid validity period, or any extension thereof pursuant to your request;
  - e. I am/we are declared ineligible or post-disqualified upon receipt of your notice to such effect, and (i) I/we failed to timely file a request for reconsideration or (ii) I/we filed a waiver to avail of said right; and
  - f. I am/we are declared the bidder with the Lowest Calculated Responsive Bid, and I/we have furnished the performance security and signed the Contract.

IN WITNESS WHEREOF, I/We have hereunto set my/our hand/s this \_\_\_\_ day of *[month]*  
*[year]* at *[place of execution]*.

*[Insert NAME OF BIDDER OR ITS AUTHORIZED  
REPRESENTATIVE]*  
*[Insert signatory's legal capacity]* Affiant

**[Jurat]**

*[Format shall be based on the latest Rules on Notarial Practice]*

*GPPB Resolution No. 16-2020, dated 16 September 2020*

Contract Agreement Form for the Procurement of Goods (Revised)

[Not required to be submitted with the Bid, but it shall be submitted within ten (10) days after receiving the Notice of Award]

CONTRACT AGREEMENT

SUPPLY, DELIVERY AND INSTALLATION OF AIR – CONDITIONING UNITS  
AT CALBAYOG AND DAVAO – ILUSTRE BRANCHES

ITB-SSS-Goods-2023-\_\_

THIS AGREEMENT made between:

SOCIAL SECURITY SYSTEM, a government-owned and controlled corporation created pursuant to Republic Act No. 11199, with principal office address at SSS Building, East Avenue, Diliman, Quezon City, represented herein by its Approving Authority and (Position of Approving Authority), (Name of Approving Authority) and (Position of Signatory), (Name of signatory), duly authorized pursuant to Administrative Order \_\_\_\_\_, \_\_\_\_\_ (pertaining to Approving Authority) (Annex “A”) and Office Order \_\_\_\_\_, \_\_\_\_\_ (Annex “B”) (pertaining to signatories), hereinafter referred to as the “SSS”;

- a n d -

(NAME OF SUPPLIER), of legal age, Filipino, single/married, with principal address at \_\_\_\_\_, hereinafter referred to as the “Supplier”.

If corporation

(NAME OF SUPPLIER), a corporation duly created and existing pursuant to the laws of the Republic of the Philippines, with principal office address at \_\_\_\_\_, represented herein by its (Position of Signatory), (Name of Signatory), duly authorized pursuant to \_\_\_\_\_, \_\_\_\_\_, hereinafter referred to as the “Supplier”.

WHEREAS, the Entity invited Bids for certain goods and ancillary services, particularly [brief description of goods and services] (PROJECT) and has accepted a Bid by the Supplier for the supply of those goods and services in the sum of [contract price in words and figures in specified currency/ (hereinafter called “the Contract Price”).

NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:

- 1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the Conditions of Contract referred to.



2. The following documents as required by the 2016 revised Implementing Rules and Regulations of Republic Act No. 9184 shall be deemed to form and be read and construed as integral part of this Agreement, viz.:

- a. Philippine Bidding Documents (PBDs);
  - i. Schedule of Requirements;
  - ii. Technical Specifications;
  - iii. General and Special Conditions of Contract; and
  - iv. Supplemental or Bid Bulletins, if any
- b. Supplier's bid, including the Eligibility requirements, Technical and Financial Proposals, and all other documents or statements submitted;

Bid form, including all the documents/statements contained in the Bidder's bidding envelopes, as annexes, and all other documents submitted (e.g., Bidder's response to request for clarifications on the bid), including corrections to the bid, if any, resulting from the Procuring Entity's bid evaluation;

- c. Performance Security;
- d. Notice of Award of Contract; and the Bidder's conforme thereto; and
- e. Other contract documents that may be required by existing laws and/or the Procuring Entity concerned in the PBDs. **Winning bidder agrees that additional contract documents or information prescribed by the GPPB that are subsequently required for submission after the contract execution, such as the Notice to Proceed, Variation Orders, and Warranty Security, shall likewise form part of the Contract.**

3. In consideration for the sum of *[total contract price in words and figures]* or such other sums as may be ascertained, *[Named of the bidder]* agrees to *[state the object of the contract]* in accordance with his/her/its Bid.
4. SSS agrees to pay the above-mentioned sum in accordance with the terms of the Bidding.

IN WITNESS whereof the parties hereto have caused this Agreement to be executed in accordance with the laws of the Republic of the Philippines on the date and place indicated in their respective acknowledgments.

*[Insert Name and Signature]*

*[Insert Name and Signature]*

*[Insert Position of Signatory]*

*[Insert Position of Signatory]*

*for:*

*for:*

SSS

*[Insert Name of Supplier]*





(In case of double acknowledgment which is usually used by the SSS)

SIGNED IN THE PRESENCE OF:

\_\_\_\_\_

(Name of Certifying officer as to availability of funds)

(Position of Certifying Officer)

(Department/Office of Certifying Officer)

FUNDS AVAILABLE:

APP No.: \_\_\_\_\_

FIRST ACKNOWLEDGMENT

Republic of the Philippines )  
\_\_\_\_\_ ) S.S.

BEFORE ME, a Notary Public for and in \_\_\_\_\_, Philippines, on this \_\_\_\_\_ day of \_\_\_\_\_ personally appeared:

Name	Competent Evidence of Identity	Date/Place of Issue

known to me to be the same person who executed the foregoing Agreement, consisting of \_\_\_\_\_ (\_\_\_\_) pages, including this page and excluding annexes, and he/she/they acknowledged to me that the same is his/her/their free and voluntary act and deed as well as the free and voluntary act and deed of the principal he/she /they represent/s in this instance.

WITNESS MY HAND AND SEAL on the date and place first above written.

Doc. No. \_\_\_\_\_;  
Page No. \_\_\_\_\_;  
Book No. \_\_\_\_\_;  
Series of 20\_\_\_\_.



SIGNED IN THE PRESENCE OF:

\_\_\_\_\_

SECOND ACKNOWLEDGMENT

Republic of the Philippines )  
\_\_\_\_\_ ) S.S.

BEFORE ME, a Notary Public for and in \_\_\_\_\_, Philippines, on this \_\_\_\_\_ day of \_\_\_\_\_ personally appeared:

Name	Competent Evidence of Identity	Date/Place of Issue

known to me to be the same person who executed the foregoing Agreement, consisting of \_\_\_\_\_ (\_\_) pages, including this page and excluding annexes, and he/she/they acknowledged to me that the same is his/her/their free and voluntary act and deed (if corporation to include succeeding phrase) as well as the free and voluntary act and deed of the principal he/she/they represent/s in this instance.

WITNESS MY HAND AND SEAL on the date and place first above written.

Doc. No. \_\_\_\_\_;  
Page No. \_\_\_\_\_;  
Book No. \_\_\_\_\_;  
Series of 20\_\_.



Omnibus Sworn Statement (Revised)

REPUBLIC OF THE PHILIPPINES)  
CITY/MUNICIPALITY OF \_\_\_\_\_) S.S.

AFFIDAVIT

I, [Name of Affiant], of legal age, [Civil Status], [Nationality], and residing at [Address of Affiant], after having been duly sworn in accordance with law, do hereby depose and state that:

1. **Select one, delete the other:**

[If a sole proprietorship:] I am the sole proprietor or authorized representative of [Name of Bidder] with office address at [address of Bidder];

[If a partnership, corporation, cooperative, or joint venture:] I am the duly authorized and designated representative of [Name of Bidder] with office address at [address of Bidder];

2. **Select one, delete the other:**

[If a sole proprietorship:] As the owner and sole proprietor, or authorized representative of [Name of Bidder], I have full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity] as shown in the attached duly notarized Special Power of Attorney;

[If a partnership, corporation, cooperative, or joint venture:] I am granted full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached [state title of attached document showing proof of authorization (e.g., duly notarized Secretary's Certificate, Board/Partnership Resolution, or Special Power of Attorney, whichever is applicable);];

3. [Name of Bidder] is not "blacklisted" or barred from bidding by the Government of the Philippines or any of its agencies, offices, corporations, or Local Government Units, foreign government/foreign or international financing institution whose blacklisting rules have been recognized by the Government Procurement Policy Board, **by itself or by relation, membership, association, affiliation, or controlling interest with another blacklisted person or entity as defined and provided for in the Uniform Guidelines on Blacklisting;**

4. Each of the documents submitted in satisfaction of the bidding requirements is an authentic copy of the original, complete, and all statements and information provided therein are true and correct;

5. [Name of Bidder] is authorizing the Head of the Procuring Entity or its duly authorized representative(s) to verify all the documents submitted;

6. **Select one, delete the rest:**

[If a sole proprietorship:] The owner or sole proprietor is not related to the Head of the Procuring Entity, Procurement Agent if engaged, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

[If a partnership or cooperative:] None of the officers and members of [Name of Bidder] is related to the Head of the Procuring Entity, Procurement Agent if engaged, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

*[If a corporation or joint venture:]* None of the officers, directors, and controlling stockholders of *[Name of Bidder]* is related to the Head of the Procuring Entity, Procurement Agent if engaged, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

7. *[Name of Bidder]* complies with existing labor laws and standards; and
8. *[Name of Bidder]* is aware of and has undertaken the responsibilities as a Bidder in compliance with the Philippine Bidding Documents, which includes:
  - a) Carefully examining all of the Bidding Documents;
  - b) Acknowledging all conditions, local or otherwise, affecting the implementation of the Contract;
  - c) Making an estimate of the facilities available and needed for the contract to be bid, if any; and
  - d) Inquiring or securing Supplemental/Bid Bulletin(s) issued for the *[Name of the Project]*.
9. *[Name of Bidder]* did not give or pay directly or indirectly, any commission, amount, fee, or any form of consideration, pecuniary or otherwise, to any person or official, personnel or representative of the government in relation to any procurement project or activity.
10. **In case advance payment was made or given, failure to perform or deliver any of the obligations and undertakings in the contract shall be sufficient grounds to constitute criminal liability for Swindling (Estafa) or the commission of fraud with unfaithfulness or abuse of confidence through misappropriating or converting any payment received by a person or entity under an obligation involving the duty to deliver certain goods or services, to the prejudice of the public and the government of the Philippines pursuant to Article 315 of Act No. 3815 s.1930, as amended, or the Revised Penal Code.**

IN WITNESS WHEREOF, I have hereunto set my hand this \_\_ day of \_\_, 20\_\_ at \_\_\_\_\_, Philippines.

*[Insert NAME OF BIDDER OR ITS AUTHORIZED REPRESENTATIVE]*

*[Insert signatory's legal capacity]*  
Affiant

**[Jurat]**

*[Format shall be based on the latest Rules on Notarial Practice]*

GPPB Resolution No. 16-2020, dated 16 September 2020

SECRETARY'S CERTIFICATE

I, <NAME OF CORPORATE SECRETARY>, of legal age, <Civil Status>, Filipino citizen and with business at <Company Address>, after being duly sworn, hereby depose and state that:

- 1. I am the Corporate Secretary of <COMPANY NAME>, a Corporation duly organized and existing under and by virtue of the laws of the Philippines, with principal office at <Office Address>.
- 2. As the Corporate Secretary, I have custody and access to the records of the Corporation.
- 3. I am familiar with the facts herein certified and duly authorized to certify the same.
- 4. I hereby certify that during a regular meeting of the Board of Directors of the Corporation held on <Date of Meeting>, at which meeting a quorum was present, the following Resolution/s was/were unanimously passed, approved and adopted:

- a) RESOLVED that <COMPANY NAME>, authorized and empowered the following to participate in the bidding for the <PROJECT NAME> of the SOCIAL SECURITY SYSTEM:

NAME	POSITION/DESIGNATION	SIGNATURE
1.		
2.		

- b) RESOLVED FURTHER that, if awarded the Contract, the following is/are granted full power and authority to enter into contract with the SOCIAL SECURITY SYSTEM:

NAME	POSITION/DESIGNATION	SIGNATURE
1.		
2.		

- c) RESOLVED FURTHERMORE that, the designated representative/s of the Corporation has/have the full power to perform any and all acts necessary and/or to represent the Corporation as fully and effectively as the Corporation might do if personally present, and hereby satisfying and confirming all the said representative/s shall lawfully do or cause to be done by virtue hereof.

IN WITNESS WHEREOF, I have hereunto set my hand this \_\_ day of \_\_\_\_ at <CITY>.

\_\_\_\_\_  
NAME & SIGNATURE of Corporate Secretary

SUBSCRIBE AND SWORN to before me this \_\_ day of \_\_\_\_\_ at <CITY>, affiant having exhibited to me his/her <Government Issued ID and details [issued by, date and place issued if applicable]>).

Doc No. \_\_\_\_\_  
Page No. \_\_\_\_\_  
Book No. \_\_\_\_\_  
Series of \_\_\_\_\_



GENERAL NOTES: MECHANICAL WORKS

1. ALL MECHANICAL DESIGN AND INSTALLATION WORKS SHALL BE IN ACCORDANCE WITH THE LATEST ASHRAE AND SMACNA STANDARDS, PSME CODE, NATIONAL BUILDING CODE AND THE CITY ORDINANCES.
2. THE TOTAL SCOPE OF WORK SHALL INCLUDE ALL WORKS DESCRIBED IN PLANS AND LISTED IN THE TECHNICAL SPECIFICATIONS FOR MECHANICAL WORKS.
3. THE WORKS SHALL BE EXECUTED IN CLOSE COORDINATION WITH ALL TRADES SUPERVISED BY ENGINEERING PRACTITIONER.
4. ALL AIR CONDITIONED SPACES SHALL BE MAINTAINED AT 24°C TO 25°C Db @ 50% ±5 RH.
5. CONTRACTOR/SUPPLIER SHALL INSTALL ALL EQUIPMENT IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATION.
6. THIS CONTRACTOR SHALL BE RESPONSIBLE FOR ALL THE BALANCING, TESTING AND COMMISSIONING OF THE WHOLE VENTILATION AND AIR CONDITIONING SYSTEM AS INSTALLED.
7. ALL POWER WIRINGS UP TO CIRCUIT BREAKER SHALL BE BY ELECTRICAL CONTRACTOR AND FROM CIRCUIT BREAKER TO EQUIPMENT BY MECHANICAL CONTRACTOR, SEE NOTE UNDER SEQUENCE OF OPERATION.
8. VERIFY LOCATION OF THERMOSTAT IN COORDINATION TO ARCHITECTURAL LOCATION.
9. PROVIDE PIPE SLEEVES FOR ALL PIPING PASSING THROUGH BUILDING STRUCTURE.
10. PIPE INSULATION SHALL BE 15mm THK ELASTOMERIC RUBBER FOR DRAIN LINES AND 25mm THK ELASTOMERIC RUBBER WITH VAPOR BARRIER FOR REFRIGERANT LINES.
11. PIPE ALL EQUIPMENT CONDENSATE DRAIN LINE TO THE NEAREST FLOOR DRAIN, DRAIN STUB-OUT OR CATCH BASIN PROVIDED BY THE PLUMBING CONTRACTOR. USE MINIMUM OF 25mm, POC DRAIN LINE.
12. ALL REFRIGERANT PIPE SHALL BE TYPE "L" HARD DRAWN COPPER TUBING FOR 5TR AND TYPE "M" FOR BELOW 5TR.
13. PITCH ALL HORIZONTAL REFRIGERATION LINE WITH A MINIMUM OF 13mm IN 3m IN THE DIRECTION OF REFRIGERANT FLOW.
14. PROVIDE OIL TRAP WHEN EVER FAN COIL UNIT ELEVATION IS BELOW THE ACCU.
15. USE THE NEXT BIGGER SIZE REFRIGERANT PIPE WHEN THE TOTAL EQUIVALENT LENGTH IS MORE THAN 25M.
16. ALL INCIDENTAL MATERIALS AND SERVICES ESSENTIAL TO THE COMPLETION OF THE PROJECT SHALL BE PROVIDED AND RENDERED AT THE CONTRACTOR'S LIABILITY AND RESPONSIBILITIES.
17. APPROPRIATE MOUNTING AND SUPPORTS SHALL BE PROVIDED TO RIGIDLY SECURE ALL INSTALLATION.

LEGEND & ABBREVIATION

ACCU	AIR-COOLED CONDENSING UNIT		EQUIPMENT NUMBER	PPAC	AIRCON POWER PANEL
FCU	FAN COIL UNIT		ENCLOSED CIRCUIT BREAKER	ECB	ENCLOSED CIRCUIT BREAKER
	AIR FLOW		DISTRIBUTION PANEL	AT	AMPERE TRIP
	AIR-COOLED CONDENSING UNIT		EXHAUST FAN	KW	KILOWATTS
	FAN COIL UNIT		AIR CURTAIN	CFM	CUBIC FEET PER MINUTE
	EQUIPMENT NUMBER		TRANSFER FAN	PH	PHASE
	WALL MOUNTED TRANSFER/EXHAUST FAN		TONS OF REFRIGERATION	HZ	HERTZ
	CEILING MOUNTED EXHAUST FAN		BRITISH THERMAL UNIT	TBD	TO BE DETERMINED
	AIR-CURTAIN		HORSE POWER	N	BRAND NEW UNIT

EQUIPMENT SCHEDULE: VENTILATING FANS

DESIGNATION	TYPE	DESCRIPTION	SUPPLY AIR CFM	MOTOR RATINGS WATTS	FAN EFFICIENCY (MINIMUM)	DRIVE	ELECTRICAL CHARACTERISTICS		LOCATION		REMARKS
							VOLTS	PHASE	FLOOR	AREA SERVED	
AC 101 - N	AP-CURTAIN	3m EFFECTIVE DISTANCE	700 (MINIMUM)	80-120	80	DIRECT	230	1	GROUND	MAIN ENTRANCE/EXIT	PROPOSED UNIT
AC 102 - N	AP-CURTAIN	3m EFFECTIVE DISTANCE	700 (MINIMUM)	80-120	80	DIRECT	230	1	GROUND	MAIN ENTRANCE/EXIT	PROPOSED UNIT
TF 101 - N	TRANSFER FAN	WALL TYPE W/ SHUTTER	300 (MINIMUM)	30-50	80	DIRECT	230	1	GROUND	ELECTRICAL ROOM	PROPOSED UNIT
TF 102 - N	TRANSFER FAN	WALL TYPE W/ SHUTTER	300 (MINIMUM)	30-50	80	DIRECT	230	1	GROUND	MECHANICAL & STORAGE ROOM	PROPOSED UNIT
TF 103 - N	TRANSFER FAN	WALL TYPE W/ SHUTTER	300 (MINIMUM)	30-50	80	DIRECT	230	1	GROUND	MECHANICAL & STORAGE ROOM	PROPOSED UNIT
EF 101 - N	EXHAUST FAN	CEILING TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	DIRECT	230	1	GROUND	PANTRY	PROPOSED UNIT
EF 102 - N	EXHAUST FAN	WALL TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	DIRECT	230	1	GROUND	FEMALE TOILET	PROPOSED UNIT
EF 103 - N	EXHAUST FAN	WALL TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	DIRECT	230	1	GROUND	MALE TOILET	PROPOSED UNIT
EF 103 - N	EXHAUST FAN	WALL TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	DIRECT	230	1	GROUND	PHO TOILET	PROPOSED UNIT


EQUIPMENT SCHEDULE: FAN COIL UNITS

DESIGNATION	DESCRIPTION	COOLING CAPACITY TR/HP	BTU/HR	BLOWER FAN DATA			APPROXIMATE PIPING LENGTH (ft)	BRAND	SERIAL NUMBER	LOCATION		REMARKS
				DRIVE	VOLT	PHASE				FLOOR	AREA SERVED	
FCU 101 - N	CEILING MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	58	TBD	GROUND	ADMINISTRATIVE SECTION	PROPOSED UNIT
FCU 102 - N	CEILING MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	58	TBD	GROUND	ACCOUNTS MANAGEMENT SECTION	PROPOSED UNIT
FCU 103 - N	CEILING MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	35	TBD	GROUND	MEDICAL EVALUATION CENTER	PROPOSED UNIT
FCU 104 - N	FLOOR MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	77	TBD	GROUND	GENERAL INFO & FORMS COUNTER, PHO	PROPOSED UNIT
FCU 105 - N	FLOOR MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	78	TBD	GROUND	MISS SEATING AREA	PROPOSED UNIT
FCU 106 - N	FLOOR MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	77	TBD	GROUND	MISS SEATING AREA	PROPOSED UNIT
FCU 107 - N	FLOOR MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	55	TBD	GROUND	MISS BACKROOM	PROPOSED UNIT
FCU 108 - N	FLOOR MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	50	TBD	GROUND	E - CENTER	PROPOSED UNIT
FCU 109 - N	WALL MOUNTED	2.5 HP	22000	DIRECT	220	1	60	52	TBD	GROUND	TELLER SECTION	PROPOSED UNIT
FCU 110 - N	WALL MOUNTED	2 HP	18000	DIRECT	220	1	60	71	TBD	GROUND	OFFICE OF THE BRANCH HEAD	PROPOSED UNIT
FCU 111 - N	WALL MOUNTED	2 HP	18000	DIRECT	220	1	60	72	TBD	GROUND	CONFERENCE ROOM	PROPOSED UNIT
FCU 112 - N	WALL MOUNTED	2 HP	18000	DIRECT	220	1	60	27	TBD	GROUND	ID CAPTURE	PROPOSED UNIT


EQUIPMENT SCHEDULE: AIR-COOLED CONDENSING UNITS

DESIGNATION	AIR DISCHARGE	NO. OF FAN	CONDENSER DATA				REFRIGERANT PIPE SIZE			BREMER DATA		POWER INPUT (kW)	SERIAL NUMBER	LOCATION		REMARKS
			DRIVE	VOLT	PHASE	HERTZ	SUCTION	DISCHARGE	AT	PHASE	FLOOR			AREA		
ACCU 101 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 102 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 103 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 104 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 105 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 106 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 107 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 108 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 109 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	30	1	18	1.7 - 1.8	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 110 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	30	1	18	1.5 - 1.8	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 111 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	30	1	18	1.5 - 1.8	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT
ACCU 112 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	30	1	18	1.5 - 1.8	TBD	GROUND	REAR OF BUILDING	PROPOSED UNIT





*Handwritten signature*



GROUND FLOOR  
**1** PROPOSED MECHANICAL LAYOUT  
 N-03 SCALE 1:125

*Handwritten signature/initials*



GENERAL NOTES: MECHANICAL WORKS

1. ALL MECHANICAL DESIGN AND INSTALLATION WORKS SHALL BE IN ACCORDANCE WITH THE LATEST ASHRAE AND SMACNA STANDARDS, PSME CODE, NATIONAL BUILDING CODE AND THE CITY ORDINANCES.

2. THE TOTAL SCOPE OF WORK SHALL INCLUDE ALL WORKS DESCRIBED IN PLANS AND LISTED IN THE TECHNICAL SPECIFICATIONS FOR MECHANICAL WORKS.

3. THE WORKS SHALL BE EXECUTED IN CLOSE COORDINATION WITH ALL TRADES SUPERVISED BY ENGINEERING PRACTITIONER.

4. ALL AIR CONDITIONED SPACES SHALL BE MAINTAINED AT 24°C TO 25°C Db @ 50% ±5 RH.

5. CONTRACTOR/SUPPLIER SHALL INSTALL ALL EQUIPMENT IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATION.

6. THIS CONTRACTOR SHALL BE RESPONSIBLE FOR ALL THE BALANCING, TESTING AND COMMISSIONING OF THE WHOLE VENTILATION AND AIR CONDITIONING SYSTEM AS INSTALLED.

7. ALL POWER WIRINGS UP TO CIRCUIT BREAKER SHALL BE BY ELECTRICAL CONTRACTOR AND FROM CIRCUIT BREAKER TO EQUIPMENT BY MECHANICAL CONTRACTOR, SEE NOTE UNDER SEQUENCE OF OPERATION.

8. VERIFY LOCATION OF THERMOSTAT IN COORDINATION TO ARCHITECTURAL LOCATION.

9. PROVIDE PIPE SLEEVES FOR ALL PIPING PASSING THROUGH BUILDING STRUCTURE.

10. PIPE INSULATION SHALL BE 15mm THK ELASTOMERIC RUBBER FOR DRAIN LINES AND 25mm THK ELASTOMERIC RUBBER WITH VAPOR BARRIER FOR REFRIGERANT LINES.

11. PIPE ALL EQUIPMENT CONDENSATE DRAIN LINE TO THE NEAREST FLOOR DRAIN, DRAIN STUB-OUT OR CATCH BASIN PROVIDED BY THE PLUMBING CONTRACTOR. USE MINIMUM OF 25mm, POC DRAIN LINE.

12. ALL REFRIGERANT PIPE SHALL BE TYPE "L" HARD DRAWN COPPER TUBING FOR 5TR AND TYPE "M" FOR BELOW 5TR.

13. PITCH ALL HORIZONTAL REFRIGERATION LINE WITH A MINIMUM OF 13mm IN 3m IN THE DIRECTION OF REFRIGERANT FLOW.

14. PROVIDE OIL TRAP WHEN EVER FAN COIL UNIT ELEVATION IS BELOW THE ACCU.

15. USE THE NEXT BIGGER SIZE REFRIGERANT PIPE WHEN THE TOTAL EQUIVALENT LENGTH IS MORE THAN 25M.

16. ALL INCIDENTAL MATERIALS AND SERVICES ESSENTIAL TO THE COMPLETION OF THE PROJECT SHALL BE PROVIDED AND RENDERED AT THE CONTRACTOR'S LIABILITY AND RESPONSIBILITIES.

17. APPROPRIATE MOUNTING AND SUPPORTS SHALL BE PROVIDED TO RIGIDLY SECURE ALL INSTALLATION.

LEGEND & ABBREVIATION

ACCU	AIR-COOLED CONDENSING UNIT		AIR-CURTAIN	HP	HORSE POWER
FCU	FAN COIL UNIT		EQUIPMENT NUMBER	AT	AMPERE TRIP
RAC	ROOM AIR-CONDITIONER		AIR FLOW	KW	KILOWATTS
	AIR-COOLED CONDENSING UNIT	EF	EXHAUST FAN	CFM	CUBIC FEET PER MINUTE
	FAN COIL UNIT	AC	AIR CURTAIN	TBD	TO BE DETERMINED
	WINDOW TYPE ROOM AIR-CONDITIONER	TR	TONS OF REFRIGERATION	N	BRAND NEW UNIT
	Ceiling Mounted Exhaust Fan	BTU	BRITISH THERMAL UNIT	R	FOR RELOCATION

EQUIPMENT SCHEDULE: VENTILATING FANS

DESIGNATION	TYPE	DESCRIPTION	SUPPLY AIR CFM	MOTOR RATING WATTS	FAN EFFICIENCY (MINIMUM)	ELECTRICAL CHARACTERISTICS		LOCATION		REMARKS
						VOLTS	PHASE	FLOOR	AREA SERVED	
AC 101 - N	AIR-CURTAIN	3m EFFECTIVE DISTANCE	700 (MINIMUM)	80-120	80	230	1	GROUND	MAIN ENTRANCE/EXIT	C/O LESSOR
AC 102 - N	AIR-CURTAIN	3m EFFECTIVE DISTANCE	700 (MINIMUM)	80-120	80	230	1	GROUND	MAIN ENTRANCE/EXIT	C/O LESSOR
EF 101 - N	EXHAUST FAN	CEILING TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	230	1	GROUND	SUPPLIES/STORAGE ROOM	C/O LESSOR
EF 102 - N	EXHAUST FAN	CEILING TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	230	1	GROUND	EMPLOYEE COMMON TOILET	C/O LESSOR
EF 103 - N	EXHAUST FAN	CEILING TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	230	1	GROUND	PMO/PUBLIC COMMON TOILET	C/O LESSOR
EF 104 - N	EXHAUST FAN	CEILING TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	230	1	GROUND	PARTY	C/O LESSOR
EF 105 - N	EXHAUST FAN	CEILING TYPE W/ SHUTTER	200 (MINIMUM)	30-50	80	230	1	GROUND	RECORDS ROOM	C/O LESSOR

EQUIPMENT SCHEDULE: ROOM AIR-CONDITIONER

DESIGNATION	DESCRIPTION	COOLING CAPACITY TR/HP	2 HP	BLOWER FAN DATA			POWER INPUT (KW)	SERIAL NUMBER	LOCATION		REMARKS
				DRIVE	VOLT	PHASE			FLOOR	AREA SERVED	
RAC 101	WINDOW TYPE ROOM AIR-CONDITIONER	2 HP	18000	DIRECT	220	1	60	780	GROUND	ELECTRICAL ROOM	SSS ACCOUNT

EQUIPMENT SCHEDULE: FAN COIL UNITS

DESIGNATION	DESCRIPTION	COOLING CAPACITY TR/HP	BTU/HR	BLOWER FAN DATA			APPROXIMATE PIPING LENGTH (M)	BRAND	SERIAL NUMBER	LOCATION		REMARKS
				DRIVE	VOLT	PHASE				FLOOR	AREA SERVED	
FCU 101 - N	CEILING MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	71	TBD	GROUND	AMS, MISS BACKROOM	SSS ACCOUNT
FCU 102 - N	CEILING MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	62	TBD	GROUND	AMS, MISS COUNTERS	SSS ACCOUNT
FCU 103 - N	CEILING MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	41	TBD	GROUND	ADMINISTRATIVE SECTION	SSS ACCOUNT
FCU 104 - R	FLOOR MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	122	TBD	GROUND	GENERAL INFO & FORMS COUNTER, E-CENTER	EXISTING UNIT FOR RELOCATION
FCU 105 - R	FLOOR MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	101	TBD	GROUND	MOBILE APP LEARNING CENTER D CAPTURE	EXISTING UNIT FOR RELOCATION
FCU 106 - N	FLOOR MOUNTED	3TR/4HP	36000	DIRECT	220	1	60	83	TBD	GROUND	FUTURE LARGE ACCOUNTS	SSS ACCOUNT
FCU 107 - N	WALL MOUNTED	2 HP	18000	DIRECT	220	1	60	44	TBD	GROUND	OFFICE OF THE BRANCH HEAD	SSS ACCOUNT
FCU 108 - N	WALL MOUNTED	2 HP	18000	DIRECT	220	1	60	48	TBD	GROUND	CONFERENCE ROOM	SSS ACCOUNT

EQUIPMENT SCHEDULE: AIR-COOLED CONDENSING UNITS

DESIGNATION	AIR DISCHARGE	CONDENSER DATA					REFRIGERANT PIPE SIZE			BIGGER DATA		POWER INPUT (KW)	SERIAL NUMBER	LOCATION		REMARKS
		NO. OF FAN	DRIVE	VOLT	PHASE	HERTZ	SUCTION	DISCHARGE	AT	PHASE	FLOOR			AREA		
ACCU 101 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	SSS ACCOUNT
ACCU 102 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	SSS ACCOUNT
ACCU 103 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	SSS ACCOUNT
ACCU 104 - R	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	EXISTING UNIT FOR RELOCATION
ACCU 105 - R	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	EXISTING UNIT FOR RELOCATION
ACCU 106 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	40	1	18	3.5 - 4.0	TBD	GROUND	REAR OF BUILDING	SSS ACCOUNT
ACCU 107 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	30	1	18	1.5 - 1.8	TBD	GROUND	REAR OF BUILDING	SSS ACCOUNT
ACCU 108 - N	HORIZONTAL	1	DIRECT	220	1	60	TBD	TBD	30	1	18	1.5 - 1.8	TBD	GROUND	REAR OF BUILDING	SSS ACCOUNT

Handwritten signature or mark.

