

# Section VII. Technical Specifications

Item	Maximum Quantity	Technical Specification	Statement of Compliance	Annex
Bidders must state in the Statement of Compliance below either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of <b>ITB</b> Clause 3.1(a)(ii) and/or <b>GCC</b> Clause 2.1(a)(ii).				
I	300 Units	Type/Model : Line-Interactive Brand : Generic Capacity : 650VA Input Voltage : 230VAC Input Voltage Range : Within 160-280VAC Frequency : 50/60 Hz (Auto Sensing) Output Voltage : 220 VAC Protection : Short Circuit, Surge Backup Time : 5 Mins. minimum at Full load Number of Outlet : Two (2) Power Outlet (min.) LED Indicator : AC/Normal Mode, Battery Mode, Overload/Fault Mode		
The bidder must submit copy of original brochure of the offered item verifiable through internet indicating full compliance to the stated technical specification requirements.				
II	REPLACEMENT OF SPARE PARTS OF UNINTERRUPTIBLE POWER SUPPLY (UPS)			
1.	10KVA, Baykee/MP1110 KVA, 1Ø	1. Panel Board Assembly 2. Exhaust Fan (220-240VAC 0.15/0.13A)		
2.	10KVA, 1Ø, Kemapower, N-C10KS	1. LCD Panel 2. Input Breaker		
3.	10KVA, 1Ø, Accupower, N-C10KS	1. Charger Board 2. Fan for Charger (NMB 3110KL 04W-B50, 2 wires)		
4.	15KVA, 3Ø, Kemapower, M33-15K	1. Exhaust Fan (220-240VAC 0.15/0.13A) 2. Exhaust Fan (24VDC 0.4A) 3. PS Board 4. Control Board 5. Battery Fuse 6. Input Fuse		
5.	20KVA, 3Ø, Kemapower, M33-20K	1. Exhaust Fan (220-240VAC 0.15/0.13A)		
6.	25KVA, 3Ø, Kemapower, M33-25K	1. PS Board 2. Control Board		
The bidder must submit certification that the spare parts to be supplied are compatible with the specified UPS brand and model. None submission of such certification shall be ground for disqualification.				