PROJECT

PREVENTIVE MAINTENANCE SERVICES OF UNINTERRUPTIBLE POWER SUPPLY (UPS) FOR TWO (2) QUARTERS AT VARIOUS SSS BRANCH OFFICES UNDER LUZON

CENTRAL II DIVISION

SUBJECT

COST ESTIMATE

Item No.	SSS Branches	UPS Capacity	1 st Quarter	2 nd Quarter	
1	Angeles	10 KVA, 1 Ø	5,000.00	5,000.00	
2	Baliuag	10 KVA, 1 Ø	5,000.00 5,000		
3	Bocaue	10 KVA, 1 Ø	5,000.00	5,000.00	
4	Dau	10 KVA, 1 Ø	5,000.00	5,000.00	
5	Malolos	15 KVA, 3 Ø	5,000.00	5,000.00	
6	Meycauayan	10 KVA, 1 Ø	5,000.00	5,000.00	
7	Olongapo	15 KVA, 3 Ø	5,000.00	5,000.00	
8	Pampanga	15 KVA, 3 Ø	X	5,000.00	
9	Sta. Maria	10 KVA, 1 Ø	5,000.00	5,000.00	
	Approved Budge	₱ 40,000.00	₱ 45,000.00		

Note: X = no PM will be conducted on the quarter.

Noted by:

Breakdown

First Quarter

₱ 40,000.00

Second Quarter

₱ 45,000.00

Grand Total Project Cost

₱ 85,000.00

Prepared by:

Reviewed by:

ELIZER V. WIGUEL

JEA/Engineer

TEDDY N. CARREON

Acting CEO III, BSSD

ELPIQUOS. DE CHAVEZ

Department Manager III, BSSD

PROJECT :

PREVENTIVE MAINTENANCE SERVICES OF UNINTERRUPTIBLE POWER SUPPLY

(UPS) FOR TWO (2) QUARTERS AT VARIOUS SSS BRANCH OFFICES UNDER LUZON

CENTRAL II DIVISION

SUBJECT

BIDDER'S PROPOSAL

SSS Branches	UPS Capacity	1 st Quarter	2 nd Quarter
Angeles	10 KVA, 1 Ø		
-Baliuag	10 KVA, 1 Ø		
Bocaue	10 KVA, 1 Ø		
Dau	10 KVA, 1 Ø		
Malolos	15 KVA, 3 Ø		
Meycauayan	10 KVA, 1 Ø		
Olongapo	15 KVA, 3 Ø		
Pampanga	15 KVA, 3 Ø	Х	
Sta. Maria	10 KVA, 1 Ø		
*	Total Bid Cost=	P	₽
	Angeles Baliuag Bocaue Dau Malolos Meycauayan Olongapo Pampanga	Angeles 10 KVA, 1 Ø Baliuag 10 KVA, 1 Ø Bocaue 10 KVA, 1 Ø Dau 10 KVA, 1 Ø Malolos 15 KVA, 3 Ø Meycauayan 10 KVA, 1 Ø Olongapo 15 KVA, 3 Ø Pampanga 15 KVA, 3 Ø Sta. Maria 10 KVA, 1 Ø	Angeles 10 KVA, 1 Ø Baliuag 10 KVA, 1 Ø Bocaue 10 KVA, 1 Ø Dau 10 KVA, 1 Ø Malolos 15 KVA, 3 Ø Meycauayan 10 KVA, 1 Ø Olongapo 15 KVA, 3 Ø Pampanga 15 KVA, 3 Ø Sta. Maria 10 KVA, 1 Ø

	8	Pampanga			15 KVA, 3 Ø	Х	
-	9	Sta. Maria			10 KVA, 1 Ø		
-		,			Total Bid Cost=	₽	P
					Note: X = no	PM will be co	nducted on the quarte
Tot	al Bid	Breakdown					
	Firs	t Quarter	=	₽			
	Sec	ond Quarter	=	₱			
Grai	Grand Total Bid Cost =		₱				
Rem	arks: P	Please provide yo	our quota	tion in e	every pay item		
Note the	e: The S BIR rul	SSS shall withho es and regulatio	ld the VA ⁻ ns.	Γ from tl	he amount payable	to these suppl	ier in accordance with
War	ranty F	Period:					
Price	e Term	:					
Deli	very Te	rm:					
Price	e validi	ty: <u>Thre</u>	e (3) mor	iths			
		Owner/Compa	nv Repre	sentativ			
		(Signature Ov					
Plea	se indi	cate below your	Business	Name,			
		d Telephone Nu			eceived		2
		ess SSS No					
B.I.R	TIN N	0			-		
Date	Recei	ved:			_		
		(Business Nam	e)		_		
	(Addr	ess and Telepho	ne Numb	er)			

PROJECT

PREVENTIVE MAINTENANCE SERVICES OF UNINTERRUPTIBLE POWER SUPPLY (UPS) FOR TWO (2) QUARTERS AT VARIOUS SSS BRANCH OFFICES UNDER LUZON CENTRAL II DIVISION

SUBJECT: TERMS OF REFERENCE (TOR)

A. SCOPE OF WORK

The contractor shall conduct the works according to the items stipulated below.

- 1. Shut down of unit.
 - 1.1 Inspection of the surrounding environment and measurement of UPS room temperature.
 - 1.2 Check tightness of terminations, connections, etc. (input/output and battery terminals)
- 2. General check-up of the unit.
 - 2.1 Visual inspection of parts and components.
 - 2.2 General cleaning of the unit.
 - 2.3 Cleaning of cooling fans and check for possible stuck-up
 - 2.4 Check soldered joints
 - 2.5 Conduct cleaning/vacuuming in the internal and external part of the unit, calibration of sensors, testing of protective alarms, tightening of electrical connections of the same.
 - 2.6 Conduct testing of parameters using appropriate testing tools.
- 3. Check-up on the battery
 - 3.1 Recording of cell float voltage and temperatures
 - 3.2 Visual inspection of each cell for any case possible damage of distortion, excessive swelling, straining or leakage at the poles or seals.
 - 3.3 Inspection of each cell for possible corrosion, loose of fittings, or damage to insulation.
 - 3.4 Physical inspection of the rack.
 - 3.5 Verify the size and dimension including specification and quantity of the battery.
 - 3.6 Test of battery on discharge
 - 3.7 Records test result and submit reports indicating the voltage, amperes frequency, running time, charging voltage, battery voltage and other necessary/vital details.
- Check-up on the battery charger/rectifier
 - 4.1 Calibration of the battery float and charge voltage
 - 4.2 Testing of battery charger capacitors
- 5. Check-up on inverter unit
 - 5.1 Measurement and recording of output voltage, output current and output frequency.
 - 5.2 Check on different parameters and calibration
 - 5.3 Resetting the relevant pre-adjustment when necessary.
- Check status of inverter, rectifier, power factor circuit, main board and other components of the UPS using appropriate tools/equipment and testing device.
- 7. Performance test
 - 7.1 Simulation of power failure to test the system on battery mode.
 - 7.2 Test of communication link between the equipment and load to verify accuracy of the measured parameters.
- 8. Render technical advice and recommendations.
- 9. Testing and commissioning.

B. FREQUENCY/SCHEDULE OF PREVENTIVE MAINTENANCE

 The conduct of Preventive Maintenance shall be conducted once every applicable quarter and shall have an interval of at least three (3) months but not to exceed the applicable period. **PROJECT**

PREVENTIVE MAINTENANCE SERVICES OF UNINTERRUPTIBLE POWER SUPPLY (UPS) FOR TWO (2) QUARTERS AT VARIOUS SSS BRANCH OFFICES UNDER LUZON **CENTRAL II DIVISION**

C. **REMEDIAL SERVICES**

For emergency calls due to unexpected and unintentional shutdown, malfunctioning or breakdown of the equipment, field engineers are available 24 hours a day, 7 days a week. Emergency call shall be attended to within the two (2) hours upon receipt of notice, either through phone (hotline), electronic communication or written letter, the service provider must address the problem by making a phone call to the concerned unit. Inspection/check-up of the unit shall be conducted and the service provider is required to submit a service report indicating technical recommendation and diagnosis within seventy two (72) hours after the call.

D. MODE OF PAYMENT

1. Quarterly; Progress Billing, upon submission of Sales Invoice and Service Reports

E. TECHNICAL REQUIREMENT OF THE SERVICE PROVIDER

The service provider shall submit a list of qualified technical personnel nominated to conduct the preventive and remedial services supported with certificate of training in the operation, maintenance and repair of UPS.

F. **PENALTY**

Failure to comply the works within the specified schedule, a liquidated damage will be imposed against the service provider in the amount equivalent to 1/10 of 1% of the project cost per calendar days of delay.

G. **OTHERS**

- All repairs to be conducted on the unit shall be reported first to BSSD. 1.
- The service provider shall submit to BSSD and branch concerned a service report indicating technical recommendations/advice for any action necessary to maintain and improve the reliability of the equipment.

Prepared by:

JEA/Engineer

Reviewed by:

Noted by:

Department Manager III, BSSD