

PROJECT: ELECTRICAL AND MECHANICAL WORKS AT THE RELOCATION SITE OF ILOILO-MOLO BRANCH

QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:

	Query/Clarifications	TWG/BAC Reply
1	About the fire protection, the mall requires a certain fee for requesting a drain output for the installation. Is the payment will be shouldered by the prospective bidder or is it included in the contract?	The payment for the draining of fire protection system is shouldered by the contractor and is included in the contract.
2	Regarding the sprinkler, does the material (riser) already exist?	There are existing branch lines installed with upright sprinkler heads. The existing lines are to be modified based on the proposed fire protection plan.
3	Is site inspection certificate included in the bidding documents?	The site inspection certificate is not required for this procurement project
4	When are we allowed for site inspection?	If you want to do a site inspection, kindly inform us first at least a day before the inspection, so we can coordinate with the branch. The site inspection can be done any time before the submission and opening of bids.

WRITTEN QUERIES:

	Query/Clarifications	TWG/BAC Reply
1	The drainage line for the air-conditioning unit in your plan/design is Over the ceiling or in the floor embedded?	The air-conditioning drain pipes are over the ceiling.
2	Can we ask for a contact person here in the Iloilo-Molo site for site inspection?	Contact person are as follows: Antonio V. Trinos, Jr.- 09778238158 Francis F. Flores- 09773360597 Stephen M. Gatchalian- 09064169382

ADDITIONAL INSTRUCTIONS/ISSUANCE:

	Particulars	Remarks
1	Revised Technical Specifications	This amends Section VII. Technical Specifications for Lot 1- Electrical Works for the Relocation Site of Iloilo-Molo Branch Annex “A-1”
2	Bid Breakdown	To be issued in Excel Format. This amends Form-02, Form-02-A, Form-02-B “Annex B” “Annex C” “Annex D”