

PROJECT: FENCE FOR TWENTY-ONE (21) SSS-OWNED VACANT LOTS AT MANILA HARBOUR CENTER (3RD ADVERTISEMENT)

WRITTEN QUERIES:

	Query/Clarifications	TWG/BAC Reply
1	For the SLCC Requirements: as per Sec.23.4.2.4 of the 2016 revised IRR "contractors under Small A and Small B categories without similar experience on the contract to be bid may be allowed to bid if the cost of such contract is not more than the Allowable Range of Contract Cost (ARCC) of their registration based on the guidelines as prescribed by the Philippine Contractors Accreditation Board (PCAB);"	Yes. Provided that contractors under Small A and Small B categories without similar experience on the contract to be bid may be allowed to bid if the cost of such contract is not more than the Allowable Range of Contract Cost (ARCC) of their registration based on the guidelines as prescribed by the PCAB, as stated in Sec.23.4.2.4 of the 2016 revised IRR of RA 9184.
2	For the major equipment: could it be 2,500Watts Generator Set or smaller capacity to use instead of 250KW?	As computed for the welding, grinder, drill and lighting load requirements, the minimum power needed to supply the work specification is at least 10,000 watts. A Genset rating of 20 Kva (20Kw) is required. This amends Section III. Bid Data Sheet, ITB Clause 10.5.e.Generator Set