

**PROJECT: SUPPLY, DELIVERY AND INSTALLATION OF AIR-CONDITIONING UNITS FOR VARIOUS DIVISIONS, BRANCHES, SERVICE OFFICES (LOT 2 – LUZON DIVISION, BRANCHES & SO) (RE – ADVERTISEMENT)**

**QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:**

	<b>Query/Clarifications</b>	<b>TWG/BAC Reply</b>
1	Are all the feeder lines re-useable?	For replacement units, only feeder line from enclosed circuit breaker (ECB) up to outdoor unit will be replaced. Feeder lines from power panel to ECB will be re-used.
2	What if the unit is new?	New feeder line will be installed from power panel up to outdoor units.
3	Regarding the Single Largest Completed Contract (SLCC), can we request to have the 5-year extended?	No.
4	Can we request for an ocular inspection, or can we have an advance plan/layout so we can check the AC locations where we are going to install the indoor and outdoor units?	Yes. But it is not a necessary requirement. Distances of all installation are indicated in the Bill of Quantities (BOQ).

**WRITTEN QUERIES:**

	<b>Query/Clarifications</b>	<b>TWG/BAC Reply</b>
1	Can we offer Multiple or mixed brands for this project?	Yes
2	For the refrigerants can we offer units with either R-410A or R32? Or follow what is indicated in the Technical Specifications on the bid docs.	Follow what is indicated in the Technical Specifications
3	For the Window Type, is it possible to have the EER lowered to at least 11 kJ/Hr- W?	No
4	<p><b>SSS Specifications:</b> <i>Statement of Single Largest Completed Contract similar to the Project to be bid equivalent to at least 50% of the Approved Budget Contract</i></p> <p><b>Change to:</b> <i>Statement of Single Largest Completed Contract similar to the Project to be bid equivalent to at least 50% of the Approved Budget Contract or at least two similar contracts whose aggregate amounts should be equivalent to at least 50% of the ABC</i></p>	No. Only single contract with amount equivalent to at least 50% of the ABC will be accepted.

**Blank Bid Breakdown:**

Soft – copy of blank bid breakdown in excel format will be issued in the bid bulletin. Bidders must input data on unprotected cells only.