

**PROJECT: VARIOUS ELECTRICAL EQUIPMENT FOR POWER SUBSTATION -
LOT 1 (RE-ADVERTISEMENT)**

QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:

	Query/Clarifications	TWG/BAC Reply
1	Will there be a schedule for site inspection?	<p>You may conduct site inspection from Monday to Friday at 8:00AM to 5:00PM</p> <p>Contact Person:</p> <p>Engr, Elmer Mescallado 0917-5792849</p> <p>Engr. Katrina Sapugay 0993-8982142</p> <p>*During Saturday, Sunday and Holiday</p> <p>Contact Person:</p> <p>EFMD Maintenance Team</p>

WRITTEN QUERIES:

	Query/Clarifications	TWG/BAC Reply
1	May we request for Site Inspection on August 22, Thursday morning or August 27, Tuesday morning? Kindly advise us who we is the contact person and contact number regarding site visit? - so we can coordinate with him/her. Thank you.	Please refer to item no. 1 above.
2	What is your Present or Existing Power Factor?	Our present power factor is 0.89 while other capacitor bank are defective and due for replacement.
3	Can we Request for an Extension of the Delivery from 60 days to 90 days?	No extension for the 60 calendar days delivery period.
4	Can we Request for an Extension of the Deadline for Submission from September 10, 2024 Tuesday to September 13, 2024 Friday ?	No.

5	<p>Clarification on page 19 of the PBD, Item 2.1 <i>"Advance payment of the contract amount is provided under Annex "D" of the revised 2016 IRR of RA No. 9184."</i></p> <p>Question: Please confirm if you allow for advance payment?</p>	<p>Under GCC Clause 2,2 of Special Condition of the Contract states that,</p> <p>"The terms of payment shall be one-time payment upon issuance of Certificate of Completion and Final Acceptance from EFMD"</p>
6	<p>In your Technical Specifications on page 32 of the PBD, under Item 1, <i>"...Bidders are required to submit detailed/shop drawings for capacitors 1 through 4, demonstrating that the enclosure is free standing, with name plates and meets NEMA 3R standards. These drawings must be signed by a Registered Electrical Engineer."</i></p> <p>Question: Will this be submitted by the winning bidder or should it be submitted during the bid proposal submission?</p>	<p>Yes, the required detailed/ shop drawing for the capacitors 1 through 4 of the technical specifications shall be submitted together with your bid proposal during the submission and opening of bids.</p>