

**ANNEX "A"**

**PROJECT: 50 HP TRANSFER PUMP AT MAIN BUILDING AND 20 HP TRANSFER PUMPS AND OTHER RELATED WORKS AT MAKATI BUILDING (3<sup>RD</sup> ADVERTISEMENT)**

**QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE HELD ON November 19, 2024**

	<b>Query/Clarifications</b>	<b>TWG/BAC Reply</b>
1	Can other type of pumps be considered as project accomplishment and be deliberate about as Similar Largest Completed Contract?	For Lot 1 yes, provided that at least 50% of the completed project is equivalent to the project for this advertisement. Projects involving all kinds of pumps will be considered.
2	Can we request an amendment regarding the motor efficiency from IE3 to IE2?	For Lot 1 and Lot 2, we maintain our requirement to IE3 as the motor efficiency.
3	Since this project is a 4 <sup>th</sup> advertisement and we joined in the previous, do we need to pay the fee for another bidding document?	If the bidder already paid for the bidding documents concerning the same previously advertised project, the bidder shall no longer pay the bidding documents for this advertisement.
4	What is the address of the SSS Makati Building	The address is 6782 SSS Makati Bldg. cor. Ayala and Rufino St., Makati City. Kindly look for Mr. Joseph Buitre for site inspection activity.