

PROJECT: Air-Conditioning Units and Air Curtains for Various SSS Branches

QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:

	Query/Clarifications	TWG/BAC Reply
1	May the bidder offer another brand based on the manufacturer's standard?	Yes, the bidder may offer another brand based on the manufacturer's standard, but we would like to clarify that SSS does not promote any specific brand. Recommendation of a specific brand is not allowed per RA 9184. Further, SSS will evaluate based on the technical specifications indicated in the bidding documents, not on the brand.
2	If the bidder wanted to join in multiple lots, is there a need to submit per envelope?	No, the bidder need not submit multiple envelopes but may compile it in one (1) envelope, but with markings on the documents pertaining to the specific lots they intend to bid on.

WRITTEN QUERIES:

	Query/Clarifications	TWG/BAC Reply
1	Can we offer the manufacturer Standard or other brand?	Yes. You may offer any brand as long as it complies with the required/technical specifications.
2	The 5TR or 6HP Floor Mounted can be waved or be exempted from the Energy Efficient/DOE Star rating Requirement?	No.
3	3TR or 4HP AC with Ceiling Mounted/Suspended FCU and horizontal discharge ACCU Rated Cooling Capacity: 10.5kW - Can we change it to 10.0kw?	No.
4	2TR or 2.5HP AC with Ceiling Mounted/Suspended FCU and horizontal discharge ACCU Rated Cooling Capacity: 6.1kW – Can we change it to 6.0kw?	No.
5	The quantity in the Price Schedule breakdown is 112 but in Section VI is 115 which will prevail?	No. The total quantity in the Price Schedule/Bid Breakdown and the quantity indicated in Section VI. Schedule of Requirements are both 115.

ADDITIONAL INSTRUCTIONS/ISSUANCE:

	Particulars	Remarks
1	Revised Annex C of Section V. Special Conditions of Contract	This amends Annex C of Section V. Special Conditions of Contract “Annex A-1”
2	Item (a) of Lot 3, Section VII. Technical Specifications. Revision of Rated Power Consumption from 5.38kW to 4.4kW	This amends item (a) of Lot 3 of Section VII. Technical Specifications.
3	Item (d) of Lot 5, Section VII. Technical Specifications. - Revision of Rated Cooling Capacity form 14.0kW to 10.0kW (34100 BTU/h) - Revision of Rated Power Consumption from 4.4kW to 3.58kW - Revision of COE/EER from 3.18 to 2.79	This amends item (d) of Lot 5 of Section VII. Technical Specifications.
4	Revised Price Schedule/Bid Breakdown of Lot 3	To be issued in Excel Format. This amends Form – 02. “Annex A-2”
5	Determination of EER/COP	Refer to “Annex A-3”