

PROJECT: FIRE DETECTION AND ALARM SYSTEM FOR SAN PABLO BUILDING

ADDITIONAL INSTRUCTION/ ISSUANCE:

	Particulars	Remarks
1	<p>Subject: Supply and Installation of Fire Detection and Alarm System for SSS San Pablo</p> <p>Regarding the abovementioned project, may we seek clarifications please for the Technical Specifications of Fire Alarm Control Panel?</p> <p>In the issued Bid Bulletin dated April 4, 2025 under Annex A-1 Technical Specifications, the Fire Alarm Control Panel (FACP) must be equipped with Fire Fighter Telephone System.</p> <p>We have found the Fire Alarm Control Panel that is the most compliant to all of the technical specifications provided in the Annex A-1 Technical Specifications. However, it cannot comply with the Fire Fighter Telephone System. The model of the FACP cannot be interfaced to a fire fighter telephone system. It will simply not work based on the model of the FACP.</p> <p>May we kindly ask please if you can revisit the technical specifications for the Fire Alarm Control Panel?</p> <p>Thank you and hope to hear from you soon.</p>	<p>In reference to your inquiry regarding the compliance of the Firefighter Telephone System for the Fire Detection and Alarm System (FDAS) for the SSS San Pablo Building, please be informed of the following:</p> <p>1. Finality of Specifications</p> <p>The technical specifications, as amended through Bid Bulletin No. 1 dated April 2, 2025, are final and binding, and all bids will be evaluated accordingly.</p> <p>2. Compliance Interpretation</p> <p>The Technical Working Group (TWG) affirms that the Fire Alarm Control Panel (FACP) must be equipped with a Firefighter Telephone System as stated in the amended Technical Specifications (Annex A-1).</p> <p>It does not strictly mandate that the telephone system be physically built in to the main FACP board or enclosure. It may be provided through an accessory or expansion module/integration.</p> <p>3. Acceptable Integration</p> <p>A Firefighter Telephone System supplied as an accessory or module, provided it is from the same brand or manufacturer of the proposed FACP are compatible and integratable, is considered compliant.</p> <p>The integration must ensure full operational functionality as part of the overall FDAS.</p>