

Technical Specifications

Item No.	Specification	Statement of Compliance	Annex
<p><i>[Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder’s statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</i></p>			
<p>The Bidders must submit brochures/ catalogues/ technical data sheet showing the required specification stated herein.</p>			
<p>Note: None submission of such brochures/ catalogues/ technical data sheet shall be ground for disqualification.</p>			
1.0	Duplex Booster Pump with Controller		
	• Flow Rate: 30 GPM		
	• Total Dynamic Head: 100 ft.		
	• Centrifugal End Suction Pump		
	• Electrical Parameters: 1.5-2.0 Hp. 3 Phase, 220-240 VAC, 60 Hz		
2.0	Duplex Transfer Pump with Controller		
	• Flow Rate: 50 GPM		
	• Total Dynamic Head: 100 ft.		
	• Centrifugal End Suction Pump		
	• Electrical Parameters: 3Hp, 3 Phase, 220-240 VAC, 60 Hz		
3.0	Fire Pump with Controller		
	• Flow Rate: 300 GPM		
	• Total Dynamic Head: 100 ft.		
	• Centrifugal End Suction Pump		
	• Electrical Parameters: 15Hp, 3 Phase, 220-240 VAC, 60 Hz		
4.0	Hydropneumatic Tank:		
	• Capacity: 119 gallons		
	• Maximum Working Pressure: 125 psi		

Masallat

Item No.	Specification	Statement of Compliance	Annex

Name: _____

Legal capacity: _____

Signature: _____

Duly authorized to sign the Bid for and behalf of: _____

Date: _____

Masculine