

PROJECT: REPLACEMENT OF VARIOUS PUMPS AT TARLAC BUILDING**QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:**

	Query/Clarifications	TWG/BAC Reply
1	Is it possible that the delivery may be extended to 120 calendar days from the original period or 90 calendar day?	Yes, the delivery period will be extended from 90 to 120 calendar days. This amends Section VI. Schedule of Requirements of the bidding documents
2	Regarding the Fire pump with controller, is this UL/FM? Is the Jockey Pump included in this item	No No
3	Regarding the voltage requirement, is it possible to submit a pump with a 220V capacity?	Yes, the acceptable voltage range is from 220-240VAC This amends Section VII Technical Specifications under items 1.0, 2.0 and 3.0 of the Electrical Parameters.
4	Is there a required RPM for item no. 1 and item no. 2	None.
5	Regarding the flow rate of 30 GPM, is that a combination for both pumps?	No, that is a requirement for each pump.
6	What is the set-up for both pumps? Are they both running or one is running and the other is standby?	The set-up of pumps shall be running alternately.
7	Is it ok if we are not going to conduct the site inspection activity/	It is not mandatory, but we strongly suggest for the bidder to conduct site inspection and verify the actual condition of the area and ensure other items are considered in their bid proposal.
8	Regarding the JVA, is it ok not to submit any supporting documents if it is not applicable?	Yes.

WRITTEN QUERIES:

	Query/Clarifications	TWG/BAC Reply
1	We would like to kindly request an extension of the delivery and	The delivery period will be extended from 90 to 120 calendar days.

	installation timeline to within 120 days, if feasible.	This amends Section VI. Schedule of Requirements of the bidding documents
2	With regard to the motor voltage specification of 230V, would it be acceptable to use a motor with a voltage rating of 220V instead?	Yes, the acceptable voltage range is from 220-240VAC. This amends Section VII Technical Specifications under items 1.0, 2.0 and 3.0 of the Electrical Parameters.
3	Kindly note that June 6 is a regular holiday Eid'l Adha. As the pre-screening of documents is currently scheduled for this date, we would like to request a possible rescheduling to a more suitable day.	Pre-screening of documents will be on 09 June 2025 from 8:00 AM to 5:00 PM.

ADDITIONAL INSTRUCTION/ ISSUANCE:

	Particulars	Remarks
1	Revised Section VII Technical Specifications under items 1.0, 2.0 and 3.0 of the Electrical Parameters	This amends Section VII Technical Specifications under items 1.0, 2.0 and 3.0 of the Electrical Parameters “Annex A-1”
2	Revised FORM-02 Price Schedule/ Bid Breakdown	This amends FORM-02 Price Schedule/ Bid Breakdown under items 1.1, 2.1 and 3.1 of the Electrical Parameters “Annex A-2”