



Republic of the Philippines
SOCIAL SECURITY SYSTEM

East Avenue, Diliman Quezon City * Trunkline Number: (+632) 8709 7198
 Email: ussaptayo@sss.gov.ph * Website: www.sss.gov.ph



BIDS AND AWARDS COMMITTEE (BAC) III

PROJECT : DISASTER RECOVERY COLLOCATION
ITB NO. : ITB-NGPA-SSS-GOODS-2026-023
SUBJECT : BID BULLETIN NO. 2
DATE : 26 MARCH 2026

Details of the bidding, as advertised:

Advertisement:	Posting at PhilGEPS & SSS Website & Conspicuous Places 04 March 2026 to 10 March 2026
Approved Budget for the Contract (ABC) and Source of Fund	₱57,517,101.00 Approved 2026 Corporate Operating Budget with Code PAP 2026-0256 of the Annual Procurement Plan (APP)
Price of BD (non-refundable)	₱27,500.00
Delivery/Completion Period	Within ninety (90) calendar days from receipt of Notice to Proceed and Signed Contract.

This addendum/Bid Bulletin No. 2 is issued to clarify, modify or amend items in the Bidding Documents (BD) as a result of the Pre-bid Conference on **18 March 2026**. This shall form an integral part of the BD.

Under Section 51.5.3 of the IRR of RA 12009, it shall be the responsibility of all those who have properly secured the BD to inquire and secure Supplemental/Bid Bulletins that may be issued by the BAC.

1. Schedule of activities as published:

- Pre-bid Conference: **Friday, 13 March 2026 at 10:00a.m.**
- Submission and opening of two (2) envelopes: **Friday, 27 March 2026 2:00 p.m. at the 2nd Floor Bidding Room, SSS Main Building, East Avenue, Diliman, Quezon City**

Revised Schedule of activities

- Deadline for the submission of written queries: **Friday, 20 March 2026**
- Issuance of Bid Bulletin No. 1–reply to queries: **Thursday, 26 March 2026**
- Pre-Screening of Documents: **Tuesday, 31 March 2026**
- Submission and opening of two (2) envelopes: **Wednesday, 08 April 2026 2:00 p.m. at the 2nd Floor Bidding Room, SSS Main Building, East Avenue, Diliman, Quezon City**

2. Amendments/Clarifications – “Annex A”

3. Documentary Requirements

a. **1st Envelope**

a.1 PhilGEPS Certificate of Registration (Platinum Membership).

In case of uploaded document/s, which validity period had already expired, submit the updated document/s.

a.2 Statement of all its Ongoing Government and Private Contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid;

For projects with Non-Disclosure Agreement, bidders are required to disclose the projects and its details using Form-05 of the Bidding Documents.

a.3 Statement of Single Largest Completed Contract (SLCC) that is similar to the procurement project to be bid, with supporting documents, equivalent to at least 50% of the ABC, completed within **five (5) years** prior to the submission and opening of bids, and whose value adjusted to current prices using the Philippine Statistics Authority (PSA) consumer price indices.

For this purpose, contracts similar to the Projects shall be: **Data Center Collocation**

SLCC should be a project without a Non-Disclosure Agreement.

a.4 Net Financial Contracting Capacity (NFCC) computation or Committed Line of Credit (form supplied)

a.5 Joint Venture Agreement (JVA), in case of Joint Venture – Class “B” Documents (Each partner of the joint venture shall submit the legal eligibility documents. The submission of technical and financial eligibility documents by any of the joint venture partners constitutes compliance)

a.6 Bid Security

a.6.1 Cash or Cashier’s/Manager’s Check - 2% of the ABC or

a.6.2 Surety Bond - 5% of the ABC or

a.6.3 Bid Securing Declaration

a.7 Technical Documents – project requirement

a.7.1 Section VI – Schedule of Requirements (pages 69-70)

a.7.2 Section VII – Statement of Compliance with the Technical Specifications (pages 71-79)

a.8 Omnibus Sworn Statement.

a.9 Foreign ownership limited to those allowed under the rules may participate in this Project, provided must submit any of the following:

a.9.1 Copy of Treaty, International or Executive Agreement; Or

a.9.2 Certification from the relevant government office of their country stating that Filipinos are allowed to participate in government procurement activities for the same item or product.

a.9.3 Certification from the DTI if the Bidder claims preference as a Domestic Bidder or Domestic Entity.

b. **2nd envelope**

b.1 Bid Form (form supplied) – pages 82 to 83

b.2 Bid Breakdown (form supplied) – page 84


c. **Additional Requirements to be submitted by the bidder with the Lowest Calculated Bid**

- c.1 Registration Certificate from Security Exchange Commission, for corporation including Articles of Incorporation and General Information Sheet, Department of Trade and Industry for sole proprietorship, or Cooperative Development Authority for cooperatives or its equivalent documents.
 - c.2 2026 Mayor's or Business permit issued by the city or municipality where the principal place of business of the prospective bidder is located, or the equivalent document for Exclusive Economic Zones or Areas.
 - c.3 Valid Tax Clearance per E.O. No. 398, s2005, as finally reviewed and approved by the Bureau of Internal Revenue (BIR).
 - c.4 Latest Audited Financial Statement filed through Electronic Filing and Payment System (EFPS)
 - c.5 Latest Income Tax Return filed through EFPS corresponding to the submitted Audited Financial Statement
 - c.6 Quarterly VAT (business tax returns) per Revenue Regulations 3-2005 for the last (6) months prior to the submission and opening of bids filed through EFPS.
4. Secretary's Certificate/Special Power of Attorney must clearly specify the name and position of the authorized representative who will:
- a. submit its bid; and
 - b. sign the contract (in case of award)
5. The award shall be issued to the bidder whose offer has been determined as the Lowest Calculated and Responsive Bid (LCRB).
6. All documents requiring notarization must be notarized by the Notary Public personally, who is duly commissioned and authorized to perform notarial acts for the current year.


Prepared by:


ROSALYN AZUL-CONDAT
Department Manager III*
BAC Secretariat Department

Concurred by:


JOSE VOLTAIRE CASTILLO
Chairperson
Technical Working Group

Approved by:


EDWIN B. DINCOG, JR.
Vice Chairperson
Bids and Awards Committee III

"Annex A"

BB No.2026-026
dated 26 March 2026

PROJECT: DISASTER RECOVERY COLLOCATION

QUERIES/CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE:

	Query/Clarifications	TWG/BAC Reply
1	May we ask if the distance is radial distance or waze distance?	The standard should be radial distance, though we will likely accept driving or road distance for major roads.
2	May we know until when we can submit questions in writing?	March 20, 2026.

WRITTEN QUERIES:

	Query/Clarifications	TWG/BAC Reply
1	<p>Relocation Services- <u>Responsibility and Scope</u></p> <p>Kindly clarify which party will be responsible for the following during the relocation process:</p> <p>A. Insurance coverage of equipment while in transit</p> <p>B. Actual transfer and handling of equipment</p>	<p>A. Winning bidder or his relocation subcontractor must insure all equipment listed in "Annex A-1" of the PBD for this project. Winning bidder must submit proof of insurance cover at least 15 days before equipment transfer activity.</p> <p>B. Winning bidder or his relocation subcontractor must perform the actual transfer activity and handling of all SSS equipment under supervision of SSS. This activity will include cable tagging, cable disconnection, equipment de-installation, transport, re-installation, and cable reconnection to new site. Activation shall be a joint activity with SSS and winning bidder.</p>

	<p><u>Migration Demarcation</u></p> <p>As this project involves migration from the existing location to the proposed data center, we would like to request a clear delineation of responsibilities between the End User and the Bidder. Specifically, we seek guidance on:</p> <p>A. Scope of work assigned to each party during equipment migration</p> <p>B. Responsibilities for disconnection, transport, installation, and reactivation</p>	<p>A. SSS shall supervise. All other activities shall be the responsibility of the winning bidder.</p> <p>B. Winning bidder or his relocation subcontractor must perform the actual transfer activity and handling of all SSS equipment under supervision of SSS. This activity will include cable tagging, cable disconnection, equipment de-installation, transport, re-installation, and cable reconnection to new site. Activation shall be a joint activity with SSS and winning bidder.</p>
2	<p>Video File Retention Requirement</p> <p>The current requirement specifies a retention period of four (4) months for video files. In this regard, we would like to respectfully request consideration to adjust the retention period to ninety (90) days instead. This request is based on standard industry practice, as most CCTV recording storage systems are typically designed and optimized to retain footage for up to 90 days.</p>	<p>Ninety (90) days shall be acceptable.</p>

ANNEXA -1 LIST OF EQUIPMENT

SYSTEM/RACK NUMBER	CONTENTS	Space Requirement			Weight (Kgs.)		Power Rating				
		Dimensions (H x W x D) in	Rack Unit/s		Per Unit	Total	Wattage		Amperage		
			Per Unit	Total			Per Unit	Total	Per Unit	Total	
2F-M2M-17	Oracle Rack 1242 P	78.74 x23.725x79.6									
	A10 Load Balancer	1.75 x 17.5 x 17.25 in	1	1	18	18	80	80	0.36	0.36	
	Oracle X8-2 Server (Part of Exadata System, see Rack 4)	1.7 x 17.2 x 29.0 in	2	2	18.1	18.1	2720	2720	12.36	12.36	
	Allied Telesis X550 Series Management Switch	1.7 x 8.3 x 13.6 in	1	1	7	7	256	256	1.16	1.16	
	Allied Telesis X550 Series Management Switch	1.7" x 18.97" x 32.39"	1RU	1	21.2	7	256	256	1.16	1.16	
	SPARC S7-2 Server	1.7 x 17.2 x 29.0 in	2	2	19	19	480	480	2.18	2.18	
	SPARC T8-1 Server	3.45 x 17.5 x 29 in	2	2	26.08	26.08	1920	1920	8.73	8.73	
	SPARC M8-8 Server	17.2 x 19 x 32.2 in	10	10	193	193	10400	10400	47.27	47.27	
2F-M2M-18	SG550XG-48T 48-PORT 10G BASE-T STACKABLE	17.3x1.7x17.72	1	2	7.4	14.8	258.8	517.6	2.13	4.26	
	Dell PowerEdge	3.4x17.1x29	1	2	9.6	19.2	250	500	4.70	9.40	
	Dell PowerStore Data Storage										
	Netscout TAPs										
	Netscout Packet Flow Switch										
	Netscout's InfiniStreamNG (ISNG)										
	Geovision 16CH Network Video Recorded										
	Geovision Biometrics										
2F-M2M-19	Oracle Rack 1242 P	78.74 x23.725x79.6									
	CISCO Nexus 9300 Top of Rack Switch	1.72 x 17.00 x 8.00 in	1	1	2.6	2.6	12.5	12.5	0.06	0.06	
	CISCO Nexus 9300 Top of Rack Switch	1.72 x 17.00 x 8.00 in	1	1	2.6	2.6	12.5	12.5	0.06	0.06	
	KVM Switch	1.72 x 19 x 6 in	1	1	6.25	6.25	100	100	0.45	0.45	
	SPARC T8-1 Server	1.7" x 18.97" x 32.39"	1RU	1	21.2	21.2	1920	0		0.00	
	SPARC T8-1 Server	3.45 x 17.5 x 29 in	2	2	26.08	26.08	1920	1920	8.73	8.73	
	SPARC M8-8 Server	17.2 x 19 x 32.2 in	10	10	193	193	10400	10400	47.27	47.27	
2F-M2M-20	OceanProtect X8000	3.4 x 17.6 x 32.3	2	2	44.42	44.42	1280.8	1280.8	10.00	10.00	
	CloudEngine 8620H	1.7 x 17.4 x 16.5	1	2	11.35	22.7	380	760	8.00	16.00	
	42U Rack	77.2 x 23.6 x 47.2	1	1							
2F-M2M-21	Oracle Rack 1242 P	78.74 x23.725x79.6									
	IBM System Networking SAN24B-5	1.7 x 17.24 x 17.45 in	1	2	9.16	18.32	150	300	0.63	1.26	
	ZFS Storage ZS7-2 - 100TB storage	3.42 x 17.5 x 29.9 in	2	4	28.6	57.2	720	1440	3.27	6.55	
	Oracle Storage DE3-24P Enclosure 39.5 TB	3.4 x 19 x 24.8 in	2	6	24	72	240	720	1.09	3.27	
	Oracle Storage DE3-24P Enclosure 24.2 TB	3.4 x 19 x 24.8 in	2	14	24	168	240	1680	1.09	7.64	
2F-M2M-22	Huawei SecoManager SCM-TS-AC-C (for DR)		2	4							
	Huawei HiSecEngine USG12004		10	20							
2F-M2M-23	Oracle Rack 1242										
	Exadata X8-2	1.7 x 17.2 x 29 in	2	10	20.7	103.5	544	2720	3.18	15.91	
	2x 24-core Intel Xeon 8260 Processors (2.4 Ghz)										
	2x 16-core Intel Xeon 5218 Processors (2.3 Ghz),										
	172.8TB Internal Storage, 576GB RAM										
Huawei Net Engine AR6280	7.28 x 29.13 x 23.03	2	4	12	24	350	700	5.00	10.00		
2F-M2N-17	Cisco Nexus 7706	15.6 x 17.3 x 32	9	9	65.9	65.9	3000	3000	13.70	13.70	
	Cisco ASR 1002x (BGP)	3.5 x 17.2 x 18.15	2	2	17.36	17.36	590	590	2.55	2.55	
	FORTIGATE 600C	1.8 x 17 x 16.4	1	1	8.5	8.5	138	138	0.62	0.62	
	FORTIGATE 601E	1.75 x 17 x 15	1	1	7.5	7.5	244	244	1.10	1.10	
	CISCO CATALYST 2960X	1.75 x 11 x 17.5	1	1	3.7	3.7	37	37	4.00	4.00	
	CISCO ROUTER 2951	3.5 x 17.25 x 18.5	2	2	13.2	13.2	340	340	5.00	5.00	
	SOLID SERVER EFFICIENT IP	1.68 x 18.97 x 22.59	1	2	12	24	350	700	1.60	3.20	
	INFOBLOX TRINZIC 1405	1.73 x 17.36 x 21.54	1	1	9.02	9.02	600	600	3.50	3.50	
	CISCO 2960S (DMZ)	1.75 x 17.7 x 11.8	1	1	4.5	4.5	36	36	1.00	1.00	
	CISCO 2960S (BGP PUBLIC LAN)	1.75 x 17.7 x 11.8	1	1	4.5	4.5	36	36	1.00	1.00	
	CISCO 2960S (DR LAN)	1.75 x 17.7 x 11.8	1	1	4.5	4.5	36	36	1.00	1.00	
	2F-M2N-18	Cisco ASR 1002x (Backhaul)	3.5 x 17.2 x 18.15	2	2	17.36	17.36	590	590	2.55	2.55
CISCO CATALYST 2950G		1.72 x 17.5 x 9.52	1	1	3	3	45	45	1.00	1.00	
CISCO CATALYST 4507		19.19 X 17.31 X 12.5	10	10	20.19	20.19	1667	1667	5.00	5.00	
2F-M2N-19	EXTERNAL FIREWALL Checkpoint Security Gateway 23500	3.5" x 17.4" x 20.84"	2	2	15.8	15.8	1600	1600	6.00	6.00	
	EXTERNAL FIREWALL (Service Unit) Checkpoint Security Gateway 23500	3.5" x 17.4" x 20.84"	2	2	15.8	15.8	1600	1600	6.00	6.00	
	WEB APPLICATION FIREWALL F5 Big IP i4600	1.72" x 17.4" x 22.5"	1	2	9.07	18.14	500	1000	4.00	8.00	
	MANAGED ENGINE DISTRIBUTION SERVER Dell Power Edge R650	1.7" x 18.97" x 32.39"	1	1	21.2	21.2	1400	1400	6.00	6.00	
2F-M2N-20	IBM 8284 model 22A	3.5 x 17.5 x 29.7 in	2	2	28.6	28.6	1810	1810	8.23	8.23	
	HMC:7042 CR9 HW Mgt Console	1.7 x 16.9 x 28.9 in	1	1	15.9	15.9	183	183	0.83	0.83	
	Flat panel console kit 1:7316 Model TF4	1.75 x 17 x 17 in	1	1	10.4	10.4	22	22	0.10	0.10	
	Model T42	1.7 x 18.7 x 17.6 in	1	1	15.6	15.6	140	140	0.64	0.64	
	IBM System Storage Sun 24B-4 Express	1.69 x 16.88 x 12.07 in	1	2	4.35	8.7	75	150	0.68	1.36	
	Microsemi SyncServer S600 (Juan Time protocol) with additional instalation requirements:	3.5 x 17.5 x 29.7 in	1	1	28.6	28.6	1810	1810	8.23	8.23	
	IBM Storwize V7000 SFF control	3.4x19x29.39 in	2	2	36.7	36.7	541	541	2.71	2.71	
2F-M2N-21	43RU Enclosure										
	Lenovo ThinkAgile MX Certified Node	3.4 x 17.5 in.x 28.3	2	4	32	64	1408	2816	6.00	12.00	

	Lenovo ThinkSystem NE2572 TOR Switch	1.7 x 17.3 x 19.2	2	2	11.4	22.8	289	578	1.58	3.16
2F-M2N-22	OceanStor 2600	3.39x17.60x19.21	2	2	17.5	17.5	2300	2300	10.00	10.00
	OceanStor 5110/5210 V5	6.95x17.60x38.40	4	4	50.5	50.5	2300	2300	10.00	10.00
	FusionCube 1000(Special Edition) 8	3.39x17.60x19.21	2	10	30	150	2300	11500	32.00	160.00
	CloudEngine 6800 switch	1.72x17.40x16.54	1	2	20.3	40.6	1840	3680	8.00	16.00
2F-M2N-23	IBM P750	6.81 x 17.3 x 28.7 in	3	9	48.7	146.1	1950	5850	8.86	26.59
	IBM P750 expansion Drawer	6.81 x 17.5 x 28 in	1	1	54	54	745	745	3.39	3.39
	Lenovo Switch	1.72 x 17.00 x 6.5 in	1	1	1.9	1.9	300	300	1.36	1.36
	IBM HMC	1.7 x 16.9 x 28.9 in	1	1	16.4	16.4	675	675	3.07	3.07
	IBM Power 8 Loaner Server	6.9 x 17.5 x 29.8 in	1	1	97	97	2300	2300	10.45	10.45
	V7000 Enclosure	3.64 x 19.0 x 24.8 in	1	1	55.4	55.4	452	452	2.05	2.05
	V7000 Expansion Enclosure	3.64 x 19.0 x 24.8 in	1	1	55.4	55.4	234	234	1.06	1.06
	IBM System Networking SAN24B-5	1.7 x 17.24 x 17.45 in	1	2	9.16	18.32	80	160	0.73	1.45
	Lenovo Servers	1.7 x 19 x 30.7 in	2	6	16	48	949	2847	12.94	38.82
	Nexus Switch	1.73 x 17.5 x 19.2 in	1	1	6.8	6.8	1100	1100	5.00	5.00
IBM Local Console Manager	1.72 x 17.00 x 8.00 in	1	1	2.6	2.6	12.5	12.5	0.06	0.06	