

Air Handling Units Equipment Schedule

AHU #	# OF UNITS	TR	Airflow CFM	EBP mm H ₂ O	EWT °C	LWT °C	Minimum (No. of EC fan)	POWER
GF-1	1	15	6,000.00	50	6.67	12	1	460V, 3P
GF-2	1	15	6,000.00	50	6.67	12	1	460V, 3P
GF-3	1	25	10,000.00	50	6.67	12	2	460V, 3P
GF-4	1	40	16,000.00	50	6.67	12	3	460V, 3P
GF-5	1	25	10,000.00	50	6.67	12	2	460V, 3P
GF-6	1	40	16,000.00	50	6.67	12	3	460V, 3P
GF-7	1	50	20,000.00	50	6.67	12	2	460V, 3P
GF-8	1	40	16,000.00	50	6.67	12	3	460V, 3P
GF-9	1	40	16,000.00	50	6.67	12	3	460V, 3P
GF-10	1	10	4,000.00	25	6.67	12	1	460V, 3P
2F-1	1	10	4,000.00	50	6.67	12	1	460V, 3P
2F-2	1	50	20,000.00	50	6.67	12	3	460V, 3P
2F-3	1	15	6,000.00	50	6.67	12	1	460V, 3P
2F-4	1	5	2,000.00	50	6.67	12	1	460V, 3P
2F-5	1	60	24,000.00	50	6.67	12	3	460V, 3P
2F-6	1	30	12,000.00	50	6.67	12	2	460V, 3P
2F-7	1	25	10,000.00	50	6.67	12	2	460V, 3P
2F-9	1	50	20,000.00	50	6.67	12	3	460V, 3P
2F-10	1	25	10,000.00	30	6.67	12	2	460V, 3P
3F to 11F-1	9	40	16,000.00	50	6.67	12	3	460V, 3P
3F to 11F-2	9	40	16,000.00	50	6.67	12	3	460V, 3P
12F-1	1	40	16,000.00	50	6.67	12	3	460V, 3P
12F-2	1	40	16,000.00	50	6.67	12	3	460V, 3P

Chilled Water Pumps Equipment Schedule

PUMP	# OF UNITS	FLOW RATE GPM	TDH ft.	POWER
CHILLED WATER PUMP	4	1075	141	460V, 3P